



Australian Government
National Measurement
Institute

NMI P 104

Test Procedure for the Elimination of Rounding Error for Weighing Instruments with Digital Indication

First edition — May 1976 (Document 104)

Second edition— July 1981 (Document 104)

Second edition, first revision — June 2001 (renamed NSC P 104)

Second edition, second revision — July 2004 (renamed NMI P 104)


Bradfield Road, Lindfield, NSW 2070

PO Box 264, Lindfield, NSW 2070

Telephone: (61 2) 8467 3600

Facsimile: (61 2) 8467 3610

Web page: <http://www.measurement.gov.au>



© Commonwealth of Australia 1976

All digital indicators associated with a weighing instrument shall be tested, without reference to any analogue indicator except for the purpose of setting zero, by applying test masses to the load receptor and observing the reading as detailed in the following four tests.

The first test is for zero alignment of the digital indicator and the zero indicator. The other three tests are for maximum permissible errors of $\pm 0.5e$, $\pm 1e$ and $\pm 1.5e$.

The following symbols are used:

- e = verification scale interval
- n = positive whole number

Each test lists the maximum permissible error and the test loads necessary to check for this error over the appropriate range of scale intervals. The test loads are related to the verification scale interval and are chosen so that the limits of the error fall at or near changeover points in the digital indicating system.

All the possible readings for each test mass are listed and the instrument is accepted or rejected, depending on which reading is indicated.

Two readings are taken at each applied load with the instrument equilibrium being disturbed before each reading.

Test 1 — Zero Test (Maximum Permissible Error = $\pm 0.25e$)

First Test Load = $0.25e$

Readings:

- e and e : reject
- 0 and e : pass to second test (limit)
- 0 and 0: pass to second test

Second Test Load = $0.75e$

Readings:

- 0 and 0: reject
- 0 and e : accept (limit)
- e and e : accept

Test 2 — Maximum Permissible Error = $\pm 0.5e$

- 0 to $50\,000e$ for class 1 instruments
- 0 to $5\,000e$ for class 2 instruments
- 0 to $500e$ for class 3 instruments
- 0 to $50e$ for class 4 instruments

Test Load = ne

Readings:

- $(n - 1)e$ and $(n - 1)e$: reject
- $(n - 1)e$ and ne : accept (limit)
- ne and ne : accept
- ne and $(n + 1)e$: accept (limit)
- $(n + 1)e$ and $(n + 1)e$: reject

Test 3 — Maximum Permissible Error = $\pm 1e$

Over $50\,000e$ and up to $200\,000e$
for class 1 instruments

Over $5\,000e$ and up to $20\,000e$
for class 2 instruments

Over $500e$ and up to $2\,000e$
for class 3 instruments

Over $50e$ and up to $200e$
for class 4 instruments

Test Load = $(n + 0.5)e$

Readings:

- $(n - 1)e$ and $(n - 1)e$: reject
- $(n - 1)e$ and ne : accept (limit)
- ne and ne : accept
- ne and $(n + 1)e$: accept
- $(n + 1)e$ and $(n + 1)e$: accept
- $(n + 1)e$ and $(n + 2)e$: accept (limit)
- $(n + 2)e$ and $(n + 2)e$: reject

Test 4 — Maximum Permissible Error = $\pm 1.5e$

- Over $200\,000e$ for class 1 instruments
- Over $20\,000e$ for class 2 instruments
- Over $2\,000e$ for class 3 instruments
- Over $200e$ for class 4 instruments

Test Load = ne

Readings:

- $(n - 2)e$ and $(n - 2)e$: reject
- $(n - 2)e$ and $(n - 1)e$: accept (limit)
- $(n - 1)e$ and $(n - 1)e$: accept
- $(n - 1)e$ and ne : accept
- ne and ne : accept
- ne and $(n + 1)e$: accept
- $(n + 1)e$ and $(n + 1)e$: accept
- $(n + 1)e$ and $(n + 2)e$: accept (limit)
- $(n + 2)e$ and $(n + 2)e$: reject