



Australian Government  
Department of Industry, Science,  
Energy and Resources

National  
Measurement  
Institute

# **NMI M 6-2**

## **Active-energy electricity meters (a.c.)**

Part 2: Test report format

June 2022

[www.measurement.gov.au](http://www.measurement.gov.au)

© Commonwealth of Australia 2010

First edition — September 2010  
Second edition — June 2022

National Measurement Institute  
Bradfield Road, Lindfield, NSW 2070  
PO Box 264, Lindfield, NSW 2070

T: +61 2 8467 3600  
F: +61 2 8467 3610  
W: [www.measurement.gov.au](http://www.measurement.gov.au)

## Preface

This document provides the test report format for active-energy electricity meters to accompany NMI M 6-1, v4.0 (June 2022) *Active-energy Electricity Meters (a.c.), Part 1: Metrological and Technical Requirements*.

This test report format may clarify NMI M 6-1, but it does not add to or alter any requirements. This document is primarily intended for use by test laboratories that are testing meters against the requirements of NMI M 6-1. This test report format is intended to make testing more efficient and consistent.

Note, the test report format provides for meters with different accuracy classes, connection types and capabilities. Refer to NMI M 6-1 to determine which tests are applicable for a particular meter.

This edition contains numerous changes from the first edition. The changes have been made to:

- align with the requirements specified in NMI M 6-1, v4.0
- update and clarify the information and results required by NMI
- increase alignment with the OIML test report format specified in OIML R 46-3.

## Contents

1	Test Information.....	1
2	Meter Information.....	1
3	Technical Specifications .....	2
4	Requirements Checklist.....	3
5	Maximum Permissible Errors.....	5
5.1	Direct-connected meters with balanced loads .....	5
5.2	Direct connected meters – single-phase load with balanced polyphase voltages .....	6
5.3	Transformer-operated meters with balanced loads .....	7
5.5	Transformer-operated meters – single-phase load with balanced polyphase voltages .....	8
6	Influence Factors and Disturbances .....	9
6.1	Voltage Variation.....	9
6.2	Frequency Variation.....	12
6.3	Harmonic Components in the Current and Voltage Circuits.....	15
6.4	Reversed Phase Sequence .....	15
6.5	Voltage Unbalance.....	16
6.6	Auxiliary Voltage $\pm 15\%$ .....	16
6.7	DC Component in the AC Circuit.....	17
6.8	Continuous Magnetic Induction of External Origin .....	18
6.9	Magnetic Induction of External Origin 0.5 mT.....	18
6.10	Electromagnetic RF Fields.....	19
6.11	Conducted RF Fields .....	20
6.12	Fast Transient Bursts.....	21
6.13	Variations due to Short-time Overcurrents .....	22
6.14	Operation of Accessories.....	23
6.15	Sub-harmonics in the AC Circuit.....	23
6.16	Odd Harmonics in the AC Circuit.....	24
6.17	Tilt at 3° in any Direction from the Vertical.....	24
6.18	Current Coil Self-heating.....	25
6.19	Alternative Usage and Phase Reversal (Balanced Two-element Driven) .....	25
6.20	Alternative Usage and Phase Reversal (Single-element Driven) .....	26
6.21	Register Friction.....	26
6.22	Register Changeover .....	27
6.23	Shock .....	27
7	Ambient Temperature Variation.....	28
7.1	Direct-connected Meters.....	28
7.2	Transformer-operated Meters.....	29
8	Internal Clocks .....	30
8.1	Synchronous .....	30
8.2	Crystal-controlled .....	30
9	Performance Tests .....	32
9.1	Optical Port Requirements.....	32
9.2	Dry Heat Test.....	32
9.3	Cold Test.....	33
9.4	Damp Heat Cyclic Test .....	34
9.5	Solar Radiation Test .....	35
9.6	Dust Test.....	36
9.7	Vibration (Sinusoidal) Test.....	36
9.8	Mechanical Shock Test.....	37
9.9	Radiated Electromagnetic Radiofrequency Fields Test without Current .....	37
9.10	Electrostatic Discharge Test .....	38
9.11	Voltage Dips and Short-term Interruptions Test .....	39
9.12	Impulse Voltage Test .....	40
9.13	AC Voltage Test.....	41

## 1 Test Information

<b>Test Report</b>	
Report reference number	
Date of issue	
Date of testing	
<b>Laboratory details</b>	
Name	
Address	
Contact details	
<b>Test specification</b>	
Standard	NMI M 6-1, v4.0 (June 2022)
<b>Client details</b>	
Applicant	
Address	

Remarks:

--

## 2 Meter Information

Manufacturer	
Model	
Serial number(s)	

Remarks:

--

### 3 Technical Specifications

#### Accuracy

Accuracy class  0.2  0.5  1  1.5

#### Temperature ranges

*Low*

*High*

Specified operating range  °C  °C

Limit range of operation  °C  °C

Storage and transportation  °C  °C

#### Connection type and design

Connection type  Direct-connected  Transformer-operated

Design type  Static  Induction

#### Electrical and measurement

Number of phases

Number of wires

Number of elements

Reference frequency  $f_{nom}$   50 Hz

Reference voltage(s)  $U_{nom}$   V AC

Basic current  $I_b$   A *(for direct-connected)*

Rated current  $I_n$   A *(for transformer-operated)*

Maximum current  $I_{max}$   A

Meter constant  *(include units)*

Measurement direction(s)  Positive  Negative

#### Enclosure and Protective Class

Enclosure type

Protective class

#### Software/Firmware

Software/firmware version

#### Internal Clock

Clock type(s)  Synchronous  Crystal

## 4 Requirements Checklist

Clause number and requirement (from NMI M 6-1)	Value / Remark	Result
<b>3</b>	<b>Units of measurement</b>	
	Valid units of measurement used	
<b>4.1</b>	<b>Minimum measured quantity</b>	
	Minimum measured quantity	N/A
	Smallest interval marked on indicator	N/A
	The minimum measured quantity has the form $1 \times 10^n$ authorised units of energy, where n is an integer	
	The smallest interval marked on indicator shall not be less than the minimum measured quantity	
<b>4.2</b>	<b>Maximum permissible variation between indicators</b>	
	No indicated difference between indications of same quantity on different indicators	
<b>4.3</b>	<b>Calculated quantities</b>	
	Indicated quantity equals value obtained using indicated values with applicable rounding	
	If rounding applied it is $\pm 0.5$ minimum measured quantity	
<b>4.6</b>	<b>Meter constant</b>	
	No error in relationship between test output and indication on display	
<b>4.7</b>	<b>Class indices (accuracy class)</b>	
	Meter classified as one of 0.2, 0.5, 1 or 1.5	
<b>5.2</b>	<b>Temperature range</b> (ranges shall comply with the minimum acceptable ranges in Table 5)	
	Specified operating range	
	Limit range of operation	
	Storage and transportation	
<b>5.7.2</b>	<b>Initial start up of the meter</b>	
	Time to start – shall be functional within 5 s	
<b>5.7.3</b>	<b>Running with no load</b>	
	Test voltage value (V AC)	N/A
	Test current value (A)	N/A
	Test period (s)	N/A
	Test output pulses – shall be no more than one	
	Rotor revolutions – may start but shall not complete a revolution	
<b>5.7.4</b>	<b>Starting</b>	
	Test current value (A)	N/A
	Meter starts and continues to register	
	Rotor revolutions – shall start and complete at least one revolution	

Clause number and requirement (from NMI M 6-1)	Value / Remark	Result
<b>7.2</b>	<b>Acting upon significant faults</b> (static meters only)	
	Either: No significant faults occur, or	
	Has capability to detect, log and communicate significant faults. Logged data kept in permanent record with date and time stamp.	
<b>7.3</b>	<b>Display</b>	
	Meter has a display which is legible whilst operating	
	Visible to consumer in normal installation position	
	There is a procedure to show all relevant elements of indicator display, with sufficient time to check them	
	Able to display quantity of energy corresponding to $I_{max}$ for at least 4 000 h without returning to same index	
	Calculated value (energy at $I_{max}$ for 4 000 h)	N/A
	Number of display digits	N/A
<b>8.1</b>	<b>Information to be displayed on meter exterior</b>	
	a) Manufacturer's name or mark	
	b) Model designation	
	c) Serial or identification number	
	d) Space for NMI pattern approval number	
	e) Number of phases, number of wires	
	f) Reference frequency	
	g) Specified operating temperature limits (if more restrictive than $-10\text{ }^{\circ}\text{C}$ to $+55\text{ }^{\circ}\text{C}$ )	
	h) Meter constant	
	i) Rated voltage	
	j) Rated currents	
	k) Class index	
	l) 'for indoor use only' if for indoor use only	
<b>8.2</b>	<b>Notices</b>	
	Any special notices or limitations of use shall be clearly marked or provided in manual	
<b>9.1</b>	<b>Verification mark</b>	
	Provision for a verification mark	
<b>9.2</b>	<b>Sealing</b>	
	Do mechanical seal protect parameters?	
	If not, solid state sealing is required:	
	Access to protected parameters protected	
	Access to protected parameters recorded	
	Records readily accessible	
	Record easily identifiable (not confused)	
	Reference record marked on meter	
	Record shall not repeat in a sequence of less than 99 alterations; record shall persist reliably for at least 2 years and persist through influence and disturbance tests	

## 5 Maximum Permissible Errors

Refer to NMI M 6-1, clause 4.8 (Tables 1 to 3).

### 5.1 Direct-connected meters with balanced loads

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement (during test)	Remark	Result
Errors shall not exceed limits (see below)		
Where applicable in both directions		

Direction of energy measurement

Current (A)	Power factor	Percentage error	Limit (±%) for class	
			1	1.5
0.05 $I_b$	1		1.5	1.5
0.1 $I_b$			1.0	1.5
0.2 $I_b$				
$I_b$				
$I_{max}$				
0.1 $I_b$	0.5 inductive		1.5	1.5
0.2 $I_b$			1.0	1.5
$I_b$				
$I_{max}$				
0.1 $I_b$	0.8 capacitive		1.5	N/A
0.2 $I_b$			1.0	N/A
$I_b$				
$I_{max}$				



## 5.2 Direct connected meters – single-phase load with balanced polyphase voltages

<b>Meter serial no.</b>		<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>	
<b>Date:</b>		<b>Time (hh:mm):</b>	

Requirement (during test)	Remark	Result
Errors shall not exceed limits (see below)		
Where applicable in both directions		

Direction of energy measurement

Phase	Current (A)	Power factor	Percentage error	Limit (±%) for class	
				1	1.5
Phase 1	0.1 $I_b$	1		2.0	2.5
	0.2 $I_b$				
	$I_b$				
	$I_{max}$				
	0.2 $I_b$	0.5 inductive		2.0	2.5
	$I_b$				
$I_{max}$					
Phase 2	0.1 $I_b$	1		2.0	2.5
	0.2 $I_b$				
	$I_b$				
	$I_{max}$				
	0.2 $I_b$	0.5 inductive		2.0	2.5
	$I_b$				
$I_{max}$					
Phase 3	0.1 $I_b$	1		2.0	2.5
	0.2 $I_b$				
	$I_b$				
	$I_{max}$				
	0.2 $I_b$	0.5 inductive		2.0	2.5
	$I_b$				
$I_{max}$					

### 5.3 Transformer-operated meters with balanced loads

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement (during test)	Remark	Result
Errors shall not exceed limits (see below)		
Where applicable in both directions		

Direction of energy measurement

Current (A)	Power factor	Percentage error	Limit (±%) for class		
			0.2	0.5	1
0.01 $I_n$	1		0.4	1.0	
0.02 $I_n$					1.5
0.05 $I_n$			0.2	0.5	1.0
0.1 $I_n$					
$I_n$					
$I_{max}$					
0.02 $I_n$	0.5 inductive		0.5	1.0	
0.05 $I_n$					1.5
0.1 $I_n$			0.3	0.6	1.0
$I_n$					
$I_{max}$					
0.02 $I_n$	0.8 capacitive		0.5	1.0	
0.05 $I_n$					1.5
0.1 $I_n$			0.3	0.6	1.0
$I_n$					
$I_{max}$					

### 5.5 Transformer-operated meters – single-phase load with balanced polyphase voltages

<b>Meter serial no.</b>		<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>	
<b>Date:</b>		<b>Time (hh:mm):</b>	

Requirement (during test)	Remark	Result
Errors shall not exceed limits (see below)		
Where applicable in both directions		

Direction of energy measurement

Phase	Current (A)	Power factor	Percentage error	Limit (±%) for class		
				0.2	0.5	1
Phase 1	0.05 $I_n$	1		0.3	0.6	2.0
	0.1 $I_n$					
	$I_n$					
	$I_{max}$	0.5 inductive		0.4	1.0	2.0
	0.1 $I_n$					
	$I_n$					
$I_{max}$						
Phase 2	0.05 $I_n$	1		0.3	0.6	2.0
	0.1 $I_n$					
	$I_n$					
	$I_{max}$	0.5 inductive		0.4	1.0	2.0
	0.1 $I_n$					
	$I_n$					
$I_{max}$						
Phase 3	0.05 $I_n$	1		0.3	0.6	2.0
	0.1 $I_n$					
	$I_n$					
	$I_{max}$	0.5 inductive		0.4	1.0	2.0
	0.1 $I_n$					
	$I_n$					
$I_{max}$						

## 6 Influence Factors and Disturbances

### 6.1 Voltage Variation

Refer to NMI M 6-1, Table 4 and A.2.12.

#### 6.1.1 Direct-connected Meters, Classes 1 and 1.5

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement	Remark	Result
Variation in error does not exceed limits (see below)		

Value of  $U_{nom}$

Voltage variation (% from $U_{nom}$ )	Current (A)	Power factor	Variation in error (%)	Limit of variation (%) by class	
				1	1.5
+10	0.05 $I_b$	1		0.7	1.0
	$I_b$				
	$I_{max}$				
	0.1 $I_b$	0.5 inductive		1.0	1.0
	$I_b$				
	$I_{max}$				
-10	0.05 $I_b$	1		0.7	1.0
	$I_b$				
	$I_{max}$				
	0.1 $I_b$	0.5 inductive		1.0	1.0
	$I_b$				
	$I_{max}$				
+15	0.05 $I_b$	1		2.1	3.0
	$I_b$				
	$I_{max}$				
	0.1 $I_b$	0.5 inductive		3.0	3.0
	$I_b$				
	$I_{max}$				
-20	0.05 $I_b$	1		2.1	3.0
	$I_b$				
	$I_{max}$				
	0.1 $I_b$	0.5 inductive		3.0	3.0
	$I_b$				
	$I_{max}$				
-50	0.05 $I_b$	1		-100 to +10	
	$I_b$				
	$I_{max}$				
	0.1 $I_b$	0.5 inductive			
	$I_b$				
	$I_{max}$				

### 6.1.2 Transformer-operated Meters, Class 1

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement	Remark	Result
Variation in error does not exceed limits (see below)		

Value of  $U_{nom}$

Voltage variation (% from $U_{nom}$ )	Current (A)	Power factor	Variation in error (%)	Limit of variation (%) by class
				1
+10	$0.02 I_n$	1		0.7
	$I_n$			
	$I_{max}$			
	$0.05 I_n$	0.5 inductive		1.0
	$I_n$			
	$I_{max}$			
-10	$0.02 I_n$	1		0.7
	$I_n$			
	$I_{max}$			
	$0.05 I_n$	0.5 inductive		1.0
	$I_n$			
	$I_{max}$			
+15	$0.02 I_n$	1		2.1
	$I_n$			
	$I_{max}$			
	$0.05 I_n$	0.5 inductive		3.0
	$I_n$			
	$I_{max}$			
-20	$0.02 I_n$	1		2.1
	$I_n$			
	$I_{max}$			
	$0.05 I_n$	0.5 inductive		3.0
	$I_n$			
	$I_{max}$			
-50	$0.02 I_n$	1		-100 to +10
	$I_n$			
	$I_{max}$			
	$0.05 I_n$	0.5 inductive		
	$I_n$			
	$I_{max}$			

### 6.1.3 Transformer-operated Meters, Classes 0.2 and 0.5

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement	Remark	Result
Variation in error does not exceed limits (see below)		

Value of  $U_{nom}$

Voltage variation (% from $U_{nom}$ )	Current (A)	Power factor	Variation in error (%)	Limit of variation (%) by class	
				0.2	0.5
+10	0.05 $I_n$	1		0.1	0.2
	$I_n$				
	$I_{max}$				
	0.1 $I_n$	0.5 inductive		0.2	0.4
	$I_n$				
	$I_{max}$				
-10	0.05 $I_n$	1		0.1	0.2
	$I_n$				
	$I_{max}$				
	0.1 $I_n$	0.5 inductive		0.2	0.4
	$I_n$				
	$I_{max}$				
+15	0.05 $I_n$	1		0.3	0.6
	$I_n$				
	$I_{max}$				
	0.1 $I_n$	0.5 inductive		0.6	1.2
	$I_n$				
	$I_{max}$				
-20	0.05 $I_n$	1		0.3	0.6
	$I_n$				
	$I_{max}$				
	0.1 $I_n$	0.5 inductive		0.6	1.2
	$I_n$				
	$I_{max}$				
-50	0.05 $I_n$	1		-100 to +10	
	$I_n$				
	$I_{max}$				
	0.1 $I_n$	0.5 inductive			
	$I_n$				
	$I_{max}$				

## 6.2 Frequency Variation

Refer to NMI M 6-1, **Table 4** and **A.2.13**.

### 6.2.1 Direct-connected meters, Classes 1 and 1.5

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

<b>Requirement</b>	<b>Remark</b>	<b>Result</b>
Variation in error does not exceed limits (see below)		

Frequency variation (%)	Current (A)	Power factor	Variation in error (%)	Limit of variation (%) by class	
				1	1.5
+2	0.05 $I_b$	1		0.5	1.0
	$I_b$				
	$I_{max}$				
	0.1 $I_b$	0.5 inductive		0.7	1.0
	$I_b$				
	$I_{max}$				
-2	0.05 $I_b$	1		0.5	1.0
	$I_b$				
	$I_{max}$				
	0.1 $I_b$	0.5 inductive		0.7	1.0
	$I_b$				
	$I_{max}$				

### 6.2.2 Transformer-operated Meters, Class 1

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

<b>Requirement</b>	<b>Remark</b>	<b>Result</b>
Variation in error does not exceed limits (see below)		

<b>Frequency variation (%)</b>	<b>Current (A)</b>	<b>Power factor</b>	<b>Variation in error (%)</b>	<b>Limit of variation (%) by class</b>
				<b>1</b>
+2	0.02 $I_n$	1		0.5
	$I_n$			
	$I_{max}$			
	0.05 $I_n$	0.5 inductive		0.7
	$I_n$			
	$I_{max}$			
-2	0.02 $I_n$	1		0.5
	$I_n$			
	$I_{max}$			
	0.05 $I_n$	0.5 inductive		0.7
	$I_n$			
	$I_{max}$			



### 6.2.3 Transformer-operated Meters, Classes 0.2 and 0.5

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

<b>Requirement</b>	<b>Remark</b>	<b>Result</b>
Variation in error does not exceed limits (see below)		

<b>Frequency variation (%)</b>	<b>Current (A)</b>	<b>Power factor</b>	<b>Variation in error (%)</b>	<b>Limit of variation (%) by class</b>	
				<b>0.2</b>	<b>0.5</b>
+2	$0.05 I_n$	1		0.1	0.2
	$I_n$				
	$I_{max}$				
	$0.1 I_n$	0.5 inductive		0.1	0.2
	$I_n$				
	$I_{max}$				
-2	$0.05 I_n$	1		0.1	0.2
	$I_n$				
	$I_{max}$				
	$0.1 I_n$	0.5 inductive		0.1	0.2
	$I_n$				
	$I_{max}$				

### 6.3 Harmonic Components in the Current and Voltage Circuits

Refer to NMI M 6-1, Table 4.

The variation in percentage error shall be measured under the most unfavourable phase displacement of the fifth harmonic in the current compared with the fundamental error.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement	Remark	Result
Variation in error does not exceed limits (see below)		

Current (A)	Power factor	Percentage error		Variation in error (%)	Limit of variation (%) by class			
		$f_{nom}$	$f_{nom} + \text{harmonics}$		0.2	0.5	1	1.5
$0.5 I_{max}$	1				0.4	0.5	0.8	1.0

### 6.4 Reversed Phase Sequence

Refer to NMI M 6-1, Table 4.

Polyphase (three-phase four wire) meters shall measure and register within the limits of variation in percentage error if any one or two phases of the three phase network are interrupted.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement	Remark	Result
Variation in error does not exceed limits (see below)		

Current (A)	Power factor	Percentage error		Variation in error (%)	Limit of variation (%) by class			
		ABC	CBA		0.2	0.5	1	1.5
$0.1 I_b (0.1 I_n)$	1				0.05	0.1	1.5	1.5

## 6.5 Voltage Unbalance

Refer to NMI M 6-1, Table 4.

Polyphase (three-phase four wire) meters shall measure and register within the limits of variation in percentage error if any one or two phases of the three phase network are interrupted.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement	Remark	Result
Variation in error does not exceed limits (see below)		

Current (A)	Power factor	Phases interrupted	Variation in error (%)	Limit of variation (%) by class		
				0.2	0.5	1
$I_b (I_n)$	1	1 phase – A		0.5	1.0	2.0
		1 phase – B				
		1 phase – C				
		2 phases – AB				
		2 phases – AC				
		2 phases – BC				

## 6.6 Auxiliary Voltage $\pm 15\%$

Refer to NMI M 6-1, Table 4.

Applicable only if the auxiliary supply is not internally connected to the voltage measuring circuit.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement	Remark	Result
Variation in error does not exceed limits (see below)		

Voltage (% from reference)	Current (A)	Power factor	Percentage error		Variation in error (%)	Limit of variation (%) by class	
			Reference	Measured		0.2	0.5
+15	$0.01 I_n$	1				0.05	0.1
-15							

## 6.7 DC Component in the AC Circuit

Refer to NMI M 6-1, **Table 4**.

This test does not apply to transformer-operated meters.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

<b>Requirement</b>	<b>Remark</b>	<b>Result</b>
Variation in error does not exceed limits (see below)		

<b>Current (A)</b>	<b>Power factor</b>	<b>Percentage error</b>		<b>Variation in error (%)</b>	<b>Limit of variation (%) by class</b>	
		$f_{\text{nom}}$	+ DC component		<b>1</b>	<b>1.5</b>
$I_{\text{max}} / \sqrt{2}$	1				3.0	6.0

## 6.8 Continuous Magnetic Induction of External Origin

Refer to NMI M 6-1, Table 4.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement	Remark	Result
Variation in error does not exceed limits (see below)		

Current (A)	Power factor	Position of magnet	Variation in error (%)	Limit of variation (%) by class			
				0.2	0.5	1	1.5
$I_b (I_n)$	1	Front		2.0	2.0	2.0	3.0
		Left-hand side					
		Right-hand side					
		Top					
		Bottom					

## 6.9 Magnetic Induction of External Origin 0.5 mT

Refer to NMI M 6-1, Table 4.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement	Remark	Result
Variation in error does not exceed limits (see below)		

Current (A)	Power factor	Variation in error (%)	Limit of variation (%) by class			
			0.2	0.5	1	1.5
$I_b (I_n)$	1		0.5	1.0	2.0	N/A
$I_b (0.5 I_n)$	1		N/A	N/A	N/A	2.0



## 6.11 Conducted RF Fields

Refer to NMI M 6-1, **Table 4** and **A.2.10**.

Meters constructed with passive elements only, including electromechanical meters, are exempt from this test.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

RF amplitude (50 Ω): 10 V (e.m.f.)  
 Modulation: 80% AM, 1 kHz sine wave  
 Frequency range: 0.15 to 80 MHz

Requirement	Remark	Result
During the test, the behaviour of the meter shall not be perturbed		
Variation in error does not exceed limits (see below)		

Current (A)	Power factor	Power port or I/O port	Variation in error (%)	Limit of variation (%) by class			
				0.2	0.5	1	1.5
$I_b (I_n)$	1			1.0	2.0	2.0	3.0

## 6.12 Fast Transient Bursts

Refer to NMI M 6-1, **Table 4** and **A.2.15**.

Meters constructed with passive elements only, including electromechanical meters, are exempt from this test. During the test, a temporary degradation or loss of function or performance is acceptable.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

- Voltage and auxiliary circuits energised with reference voltage.

<b>Requirement (during test)</b>	<b>Remark</b>	<b>Result</b>
Variation in error does not exceed limits (see below)		

<b>Current (A)</b>	<b>Power factor</b>	<b>Limit of variation (%) by class</b>			
		<b>0.2</b>	<b>0.5</b>	<b>1</b>	<b>1.5</b>
$I_b (I_n)$	1	1.0	2.0	4.0	6.0

<b>Circuit</b>	<b>Voltage peak (kV)</b>	<b>Polarity (60 s at each)</b>	<b>Variation in error (%)</b>	<b>Limit of variation (%)</b>
Voltage	4	Positive		
		Negative		
Current	4	Positive		
		Negative		
Auxiliary circuit	2	Positive		
		Negative		



### 6.13 Variations due to Short-time Overcurrents

Refer to NMI M 6-1, Table 4 and A.2.16.

<b>Meter serial no.</b>		<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>	
<b>Date:</b>		<b>Time (hh:mm):</b>	

#### 6.13.1 Test A

Requirement		Remark		Result						
Variation in error does not exceed limits (see below)										
Current (A)	Power factor	Test	Over-current value (A)	Duration (ms)	Phase	Variation in error (%)	Limit of variation (%) by class			
							0.2	0.5	1	1.5
$I_b$	1	A	$30 I_{max}$	10	1		N/A	N/A	1.5	1.5
					2					
					3					

#### 6.13.2 Test B

Requirement		Remark		Result						
Variation in error does not exceed limits (see below)										
Current (A)	Power factor	Test	Over-current value (A)	Duration (ms)	Phase	Variation in error (%)	Limit of variation (%) by class			
							0.2	0.5	1	1.5
$I_n$	1	B	$20 I_{max}$	500	1		0.05	0.05	0.5	N/A
					2					
					3					

#### 6.13.3 Tests C

- 250 A, 60 ms

Requirement	Remark	Result
No damage to surrounding equipment		

#### 6.13.4 Tests D

- 50 A, 60 ms

Requirement	Remark	Result
No damage to surrounding equipment		

## 6.14 Operation of Accessories

Refer to NMI M 6-1, Table 4.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement	Remark	Result
Variation in error does not exceed limits (see below)		

- Accessories are continuously operated
- Value of current is  $0.05 I_b$  for class 1 direct-connected meters,  $0.05 I_n$  for class 1 transformer-operated meters, and  $0.01 I_n$  for class 0.2 / class 0.5 transformer-operated meters.

Current (A)	Power factor	Accessory	Variation in error (%)	Limit of variation (%) by class			
				0.2	0.5	1	1.5
	1			0.05	0.1	0.5	1.0

## 6.15 Sub-harmonics in the AC Circuit

Refer to NMI M 6-1, Table 4 and A.2.17.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Test waveform: sinusoid, 2 cycles on, 2 cycles off

Current amplitude:  $2 \times$  reference current

Requirement	Remark	Result
Variation in error does not exceed limits (see below)		

Current (A)	Power factor	Percentage error		Variation in error (%)	Limit of variation (%) by class			
		$f_{nom}$	Test waveform		0.2	0.5	1	1.5
$0.5 I_b$ ( $0.5 I_n$ )	1				0.5	0.75	1.5	3.0

## 6.16 Odd Harmonics in the AC Circuit

Refer to NMI M 6-1, Table 4 and A.2.18.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Test waveform: sinusoid, set to zero for first and third quarters of each period

Current amplitude:  $2 \times$  reference current

Requirement	Remark	Result
Variation in error does not exceed limits (see below)		

Current (A)	Power factor	Percentage error		Variation in error (%)	Limit of variation (%) by class			
		$f_{nom}$	Test waveform		0.2	0.5	1	1.5
$0.5 I_b$ ( $0.5 I_n$ )	1				0.4	0.5	0.8	1.0

## 6.17 Tilt at 3° in any Direction from the Vertical

Refer to NMI M 6-1, Table 4.

This test is only required for induction meters and any other meters which may be influenced by their working position.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement	Remark	Result
Variation in error does not exceed limits (see below)		

Current (A)	Power factor	Direction of 3° tilt	Variation in error (%)	Limit of variation (%) by class			
				0.2	0.5	1	1.5
$0.1 I_b$	1	Forward		1.0	2.0	2.0	3.0
		Backward					
		Left					
		Right					

### 6.18 Current Coil Self-heating

Refer to NMI M 6-1, **Table 4**.

This test is only required for induction meters and any other meters which may be influenced by their working position.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Initial error: determine for each load while current coil is still unheated

Preconditioning: 1 h with voltage circuit at  $U_{nom}$ , current circuit with zero current

Test: continue until error becomes constant

Requirement	Remark	Result
Variation in error does not exceed limits (see below)		

Current (A)	Power factor	Percentage error		Variation in error (%)	Limit of variation (%) by class
		Coil unheated (initial error)	Coil heated		1.5
$I_{max}$	1				1.0
$I_{max}$	0.5 inductive				1.0

### 6.19 Alternative Usage and Phase Reversal (Balanced Two-element Driven)

Refer to NMI M 6-1, **Table 4**.

This test is only required for induction meters and any other meters which may be influenced by their working position.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement	Remark	Result
Variation in error does not exceed limits (see below)		

Current (A)	Power factor	Phase sequence	Percentage error	Variation in error (%)	Limit of variation (%) by class
					1.5
$0.05 I_b$	1	A1 leading A2 by 180°			1.0
		A1 leading A2 by 120°			
		A2 leading A1 by 120°			
$I_b$	1	A1 leading A2 by 180°			0.5
		A1 leading A2 by 120°			
		A2 leading A1 by 120°			

## 6.20 Alternative Usage and Phase Reversal (Single-element Driven)

Refer to NMI M 6-1, **Table 4**.

This test is only required for induction meters and any other meters which may be influenced by their working position.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement	Remark	Result
Variation in error does not exceed limits (see below)		

Current (A)	Power factor	Phase sequence	Percentage error	Variation in error (%)	Limit of variation (%) by class
					1.5
0.1 $I_b$	1	A1 leading A2 by 180°		N/A	N/A
		A1 leading A2 by 120°			1.0
		A2 leading A1 by 120°			
2 $I_b$	1	A1 leading A2 by 180°		N/A	N/A
		A1 leading A2 by 120°			0.5
		A2 leading A1 by 120°			

## 6.21 Register Friction

Refer to NMI M 6-1, **Table 4**.

This test is only required for induction meters and any other meters which may be influenced by their working position. For a multi-rate meter, the changeover device shall be in each operating condition in turn.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement	Remark	Result
Variation in error does not exceed limits (see below)		

Current (A)	Power factor	Changeover device operating condition	Rotor Speed		Variation in error (%)	Limit of variation (%) by class
			Heaviest load	Register disengaged		1.5
0.05 $I_b$	1					0.5

## 6.22 Register Changeover

Refer to NMI M 6-1, Table 4.

This test is only required for induction meters and any other meters which may be influenced by their working position.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement	Remark	Result
Variation in error does not exceed limits (see below)		

Current (A)	Power factor	Changeover device operating condition	Rotor Speed	Variation in error (%)	Limit of variation (%) by class
					1.5
0.05 $I_b$	1			N/A	N/A
					0.4*

\* An additional variation of 0.5% may be permitted for certain multiple-element meters (refer to AS 1284.1, clause 4.3.15).

## 6.23 Shock

Refer to NMI M 6-1, Table 4.

This test is only required for induction meters and any other meters which may be influenced by their working position.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement	Remark	Result
Variation in error does not exceed limits (see below)		

Initial error: determine for each load prior to subjecting to shock

Current (A)	Power factor	Initial error (before shock)	After shock test	Variation in error (%)	Limit of variation (%) by class
					1.5
0.05 $I_b$	1				0.5
$I_b$	1				0.3
$I_b$	0.5 inductive				0.3

## 7 Ambient Temperature Variation

Refer to NMI M 6-1, **Table 6** and **A.2.3**.

The meter error shall be determined at a minimum of four temperature values across the whole operating range. The mean temperature coefficient shall then be determined for each of the temperature intervals between successive temperature values.

In the tables below:

- $T_L$  is the lower temperature in the range
- $T_U$  is the upper temperature in the range
- $e_L$  is the error at the lower temperature in the range
- $e_U$  is the error at the upper temperature in the range
- Mean temperature coefficient is calculated as  $\frac{e_U - e_L}{T_U - T_L}$

### 7.1 Direct-connected Meters

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement (during test)	Remark	Result
The mean temperature coefficient shall not exceed the limits (see below)		
At least four temperature ranges that span the operating temperature range		

Current (A)	Power factor	Mean temperature coefficient (%/°C) by class	
		1	1.5
0.1 $I_b$ to $I_{max}$	1	0.05	0.05
0.2 $I_b$ to $I_{max}$	0.5 inductive	0.07	0.07

Temperature Range	$T_L$ (°C)	$T_U$ (°C)
Temperatures		

Current (A)	Power factor	Percentage error		Mean temperature coefficient (%/°C)	
		$e_L$	$e_U$	Calculated	Limit
0.1 $I_b$	1				
$I_b$					
$I_{max}$					
0.2 $I_b$	0.5 inductive				
$I_b$					
$I_{max}$					

*(Repeat for all temperature ranges)*

## 7.2 Transformer-operated Meters

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Requirement (during test)	Remark	Result
The mean temperature coefficient shall not exceed the limits (see below)		
At least four temperature ranges that span the operating temperature range		

Current (A)	Power factor	Mean temperature coefficient (%/°C) by class			
		0.2	0.5	1	1.5
0.05 $I_n$ to $I_{max}$	1	0.01	0.03	0.05	0.05
0.1 $I_n$ to $I_{max}$	0.5 inductive	0.02	0.05	0.07	0.07

Temperature Range	$T_L$ (°C)	$T_U$ (°C)
Temperatures		

Current (A)	Power factor	Percentage error		Mean temperature coefficient (%/°C)	
		$e_L$	$e_U$	Calculated	Limit
0.05 $I_n$	1				
$I_n$					
$I_{max}$					
0.1 $I_n$	0.5 inductive				
$I_n$					
$I_{max}$					

(Repeat for all temperature ranges)



## 8 Internal Clocks

Refer to NMI M 6-1, **clause 6**.

This test applies to all solid state internal clock intended for use for trade.

### 8.1 Synchronous

#### 8.1.1 Mains Supply

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>				
<b>Date:</b>				
			<b>Temperature (°C):</b>	
			<b>Time (hh:mm):</b>	

Testing period: 30 days

Test temperature: 23 °C

Date		Time		Difference (s)	Variation (s/day)	
		Ref	Test		Result	Limit
Start						0.167
End						

#### 8.1.2 Operational Reserve

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>				
<b>Date:</b>				
			<b>Temperature (°C):</b>	
			<b>Time (hh:mm):</b>	

Testing period: 36 h

Test temperature: 23 °C

Spring       battery/super-capacitor/primary cell

Date		Time		Difference (s)	Variation (s/day)		
		Ref	Test		Result	Limit - Spring	Limit - Battery
Start						120	1
End							

## 8.2 Crystal-controlled

#### 8.2.1 Mains Supply

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>				
<b>Date:</b>				
			<b>Temperature (°C):</b>	
			<b>Time (hh:mm):</b>	

Testing period: 30 days

Test temperature: 23 °C

Date		Time		Difference (s)	Variation (s/day)	
		Ref	Test		Result	Limit
Start						0.5
End						

### 8.2.2 Operational Reserve

<b>Meter serial no.</b>	
<b>Observer:</b>	
<b>Date:</b>	

	<b>At start</b>	<b>At end</b>
<b>Temperature (°C):</b>		
<b>Time (hh:mm):</b>		

Testing period: 36 h  
 Test temperature: 23 °C

Date		Time		Difference (s)	Variation (s/day)	
		Ref	Test		Result	Limit
Start						
End						1

### 8.2.3 High Temperature

<b>Meter serial no.</b>	
<b>Observer:</b>	
<b>Date:</b>	

	<b>At start</b>	<b>At end</b>
<b>Temperature (°C):</b>		
<b>Time (hh:mm):</b>		

Testing period: 24 h  
 Test temperature: 45 °C

Date		Time		Difference (s)	Variation (s/day)	
		Ref	Test		Result	Limit
Start						
End						0.15

### 8.2.4 Low Temperature

<b>Meter serial no.</b>	
<b>Observer:</b>	
<b>Date:</b>	

	<b>At start</b>	<b>At end</b>
<b>Temperature (°C):</b>		
<b>Time (hh:mm):</b>		

Testing period: 24 h  
 Test temperature: -10 °C

Date		Time		Difference (s)	Variation (s/day)	
		Ref	Test		Result	Limit
Start						
End						0.15

### 8.3 Other requirements

Requirement	Remark	Result
Meters must demonstrate a convenient methodology of clock synchronisation via the local optical or serial port.		
For meters recording load profile for tariff calculation, the clock synchronisation must not permit clock adjustment that crosses an interval boundary.		

## 9 Performance Tests

### 9.1 Optical Port Requirements

Refer to NMI M 6-1, 7.4 and A.1.3. AS 62056.21, 4.3.5.4 and 5.2.

Requirement	Remark	Result
The optical path (data transmission) shall not be affected by surrounding light of intensity 16 000 lux.		
Transmission speed		

### 9.2 Dry Heat Test

Refer to NMI M 6-1, A.2.1.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Duration: 72 h

Meter/EUT: In operating condition except whilst temperature is lowered or raised.

High temperature:

Requirement (during test)	Remark	Result
Error shall not exceed limits (see below) taking into account appropriate temperature coefficient		

Requirement (after test)	Remark	Result
No damage to meter		
No change of information		
Meter shall operate correctly (see below)		

Current (A)	Power factor	Percentage error			MPE by class			
		At reference before heat	At high temperature after 72 h	Reference after recovery	0.2	0.5	1	1.5
$I_b (I_n)$	1				0.2	0.5	1	1.5

### 9.3 Cold Test

Refer to NMI M 6-1, A.2.2.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Duration: 72 h

Meter/EUT: In operating condition except whilst temperature is lowered or raised.

Low temperature:

Requirement (during test)	Remark	Result
Error shall not exceed limits (see below) taking into account appropriate temperature coefficient		

Requirement (after test)	Remark	Result
No damage to meter		
No change of information		
Meter shall operate correctly (see below)		

Current (A)	Power factor	Percentage error			MPE by class			
		At reference before heat	At low temperature after 72 h	Reference after recovery	0.2	0.5	1	1.5
$I_b (I_n)$	1				0.2	0.5	1	1.5

## 9.4 Damp Heat Cyclic Test

### 9.4.1 Damp Heat Cyclic Test

Refer to NMI M 6-1, A.2.4.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Duration (cycles):  $6 \times 24$  h cycles

Meter/EUT: non-operating condition

Low temperature: 25 °C

High temperature:

Requirement	Remark	Result
No trace of corrosion likely to affect the functional properties of the EUT shall be present		

24 h after the end of this test, submit the EUT to the following tests.

### 9.4.2 AC Voltage Test

NMI M 6-1, A.2.20 – refer to clause 8.13.

### 9.4.3 Impulse Voltage Test

NMI M 6-1, A.2.19, except 0.8 of impulse voltage

Refer to NMI M 6-1, A.2.19.

Impulse waveform at no load: 1.2/50 impulse

Meter/EUT: non-operating condition

#### 9.4.3.1 For circuits and between circuits

Impulse voltage: 9.6 kV +0%, -15%

Source capacitance: 0.125  $\mu$ F

Source impedance:  $40 \Omega \pm 5 \Omega$

Stored energy: 9.0 J  $\pm$  1.0 J

Requirement (during the test)	Remark	Result
No flashover, disruptive discharge or puncture		

Requirement (after the test)	Remark	Result
No mechanical damage to the EUT		
Variation in in error does not exceed the uncertainty of measurement (see below)		

Current (A)	Power factor	Percentage error		Variation in error (%)	Limit
		Before	After		
$I_b (I_n)$	1				

**9.4.3.2 For electric circuits relative to earth**

Impulse voltage: 8 kV +0%, -10%  
 Source impedance: 500 Ω ± 50 Ω  
 Stored energy: 0.5 J ± 0.05 J

Requirement (during the test)	Remark	Result
No flashover, disruptive discharge or puncture		

Requirement (after the test)	Remark	Result
No mechanical damage to the EUT		
Variation in in error does not exceed the uncertainty of measurement (see below)		

Current (A)	Power factor	Percentage error		Variation in error (%)	Limit
		Before	After		
$I_b (I_n)$	1				

**9.5 Solar Radiation Test**

Refer to NMI M 6-1, A.2.5.

<b>Meter serial no.</b>		<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>	
<b>Date:</b>		<b>Time (hh:mm):</b>	

UV lamp output: 21 750 lm to 27 000 lm  
 Duration: 48 h and distance of 250 mm  
 Meter/EUT: non-operating condition

Requirement	Remark	Result
For transparent parts – no noticeable deterioration or loss in transparency		
For non-transparent parts – no noticeable effect		
The function of the meter shall not be impaired (see below)		

Current (A)	Power factor	Percentage error	MPE by class			
			0.2	0.5	1	1.5
$I_b (I_n)$	1		0.2	0.5	1	1.5

## 9.6 Dust Test

Refer to NMI M 6-1, A.2.6.

<b>Meter serial no.</b>	
<b>Observer:</b>	
<b>Date:</b>	

	<b>At start</b>	<b>At end</b>
<b>Temperature (°C):</b>		
<b>Time (hh:mm):</b>		

Enclosure category: 2

Duration: 8 h

Meter/EUT: non-operating condition

Requirement	Remark	Result
No dust accumulation which could affect meter operation or safety		
No dust deposition that could lead to tracking along creepage distances		
The function of the meter shall not be impaired (see below)		

Current (A)	Power factor	Percentage error	MPE by class			
			0.2	0.5	1	1.5
$I_b (I_n)$	1		0.2	0.5	1	1.5

## 9.7 Vibration (Sinusoidal) Test

Refer to NMI M 6-1, A.2.7.

<b>Meter serial no.</b>	
<b>Observer:</b>	
<b>Date:</b>	

	<b>At start</b>	<b>At end</b>
<b>Temperature (°C):</b>		
<b>Time (hh:mm):</b>		

Severity level: 2

Frequency range: 10 to 150 Hz

Max acceleration level: 10 m/s<sup>2</sup>

No sweep cycles per axis: 10

Meter/EUT: non-operating condition

Requirement	Remark	Result
No damage to meter		
No change of information		
Meter shall operate correctly (see below)		

Current (A)	Power factor	Percentage error	MPE by class			
			0.2	0.5	1	1.5
$I_b (I_n)$	1		0.2	0.5	1	1.5

## 9.8 Mechanical Shock Test

Refer to NMI M 6-1, A.2.8.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Severity level: 1  
 Pulse shape: half-sine  
 Peak acceleration: 200 m/s<sup>2</sup>  
 Pulse duration: 18 ms  
 Meter/EUT: non-operating condition, without packing

Requirement	Remark	Result
No damage to meter		
No change of information		
Meter shall operate correctly (see below)		

Current (A)	Power factor	Percentage error	MPE by class			
			0.2	0.5	1	1.5
$I_b (I_n)$	1		0.2	0.5	1	1.5

## 9.9 Radiated Electromagnetic Radiofrequency Fields Test without Current

Refer to NMI M 6-1, A.2.9.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Frequency range: 80 to 2400 MHz (continuous)  
 Modulation: 80% AM, 1 kHz sine wave  
 Field strength: 30 V/m  
 Meter/EUT: in operating condition, reference voltage, current terminal open-circuit

Requirement	Remark	Result
The behaviour of the equipment shall not be perturbed		



## 9.10 Electrostatic Discharge Test

Refer to NMI M 6-1, A.2.11.

<b>Meter serial no.</b>		<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>	
<b>Date:</b>		<b>Time (hh:mm):</b>	

Number of discharges: at least 10

Polarity of discharges: the most sensitive polarity

Severity level: 4

Meter/EUT: in operating condition, reference voltage, current terminal open-circuit

Application	Discharge mode	Test voltage (kV)	Polarity	No. of discharges	Change in Register	Change in test output	Limit, $x$ (kW·h)	Result
Direct	Contact							
Direct	Air							
Indirect, Horizontal coupling plane	Contact							
Indirect, Vertical coupling plane	Contact							

Remarks:

--

Requirement (after test)	Remark	Result
No damage		
Meter shall operate correctly (see below)		

Current (A)	Power factor	Percentage error	MPE by class			
			0.2	0.5	1	1.5
$I_b (I_n)$	1		0.2	0.5	1	1.5

## 9.11 Voltage Dips and Short-term Interruptions Test

Refer to NMI M 6-1, A.2.14.

<b>Meter serial no.</b>			<b>At start</b>	<b>At end</b>
<b>Observer:</b>		<b>Temperature (°C):</b>		
<b>Date:</b>		<b>Time (hh:mm):</b>		

Meter/EUT:     in operating condition, reference voltage, no current

$\Delta U$	Duration	Number of interruptions	Restoring time	Change in Register	Change in test output	Limit, $x$ (kW·h)	Result
100%	1 s	3	50 ms				
100%	20 ms	1	n/a				
50%	1 min	1	n/a				

Remarks:

--

## 9.12 Impulse Voltage Test

Refer to NMI M 6-1, A.2.19.

<b>Meter serial no.</b>	
<b>Observer:</b>	
<b>Date:</b>	

	<b>At start</b>	<b>At end</b>
<b>Temperature (°C):</b>		
<b>Time (hh:mm):</b>		

Impulse waveform at no load: 1.2/50 impulse

Meter/EUT: non-operating condition

### 9.12.1 For circuits and between circuits

Impulse voltage: 12 kV +0%, -15%

Source capacitance: 0.125  $\mu$ F

Source impedance: 40  $\Omega \pm 5 \Omega$

Stored energy: 9.0 J  $\pm 1.0$  J

Requirement (during the test)	Remark	Result
No flashover, disruptive discharge or puncture		

Requirement (after the test)	Remark	Result
No mechanical damage to the EUT		
Variation in in error does not exceed the uncertainty of measurement (see below)		

Current (A)	Power factor	Percentage error		Variation in error (%)	Limit
		Before	After		
$I_b (I_n)$	1				

### 9.12.2 For electric circuits relative to earth

Impulse voltage: 10 kV +0%, -10%

Source impedance: 500  $\Omega \pm 50 \Omega$

Stored energy: 0.5 J  $\pm 0.05$  J

Requirement (during the test)	Remark	Result
No flashover, disruptive discharge or puncture		

Requirement (after the test)	Remark	Result
No mechanical damage to the EUT		
Variation in in error does not exceed the uncertainty of measurement (see below)		

Current (A)	Power factor	Percentage error		Variation in error (%)	Limit
		Before	After		
$I_b (I_n)$	1				

### 9.13 AC Voltage Test

Refer to NMI M 6-1, A.2.20.

*This test is performed as part of the damp heat cyclic test (refer to NMI M 6-1, A.2.4).*

Requirement (during the test)	Remark	Result
2 kV: during the test, no flashover, disruptive discharge or puncture shall occur		
4 kV: during the test, no flashover, disruptive discharge or puncture shall occur		
40 V: during the test, no flashover, disruptive discharge or puncture shall occur		

Requirement (after the test)	Remark	Result
No mechanical damage to the EUT		
Variation in in error does not exceed the uncertainty of measurement (see below)		

Current (A)	Power factor	Percentage error		Variation in error (%)	Limit
		Before	After		
$I_b (I_n)$	1				