Premises Standards Review Recommetions and Response

Recommendation	Standard	Response
1. Amend the Disability (Access to Premises – Buildings) Standards 2010 (the Standards) where necessary to clarify policy intent, improve interpretation and reflect updates to the National Construction Code (the NCC), and consider options to harmonise with the Transport Standards where appropriate.		Supported in Principle: The Australian Government will implement 21 of the 30 technical and editorial amendments to the Standards set out in Appendix 7 of the Review Report (refer below for details); support in principle six of the remaining proposed amendments subject to the completion of Regulatory Impact Assessment (RIA); note two recommendations and issue a proposal to Standards Australia to review and update AS 1428.1; and does not support the proposed change to clause A2.2 of the Standards. Refer to the response to Appendix 7.
1.a. The Standards be updated to reflect revisions to the specification of passenger lift types in the NCC (Section 2.4 of the Review of the Disability (Access to Premises - Buildings Standards) 2010 Report (Review Report)).	Part E3 - Table E3.6(a)	Supported
1.b. Subclause D3.10(3) of the Standards be amended to provide clarification by removing the words "in length" (Section 2.5 of the Review Report).	D3.10(3)	Supported
1.c. The Department of Industry, Innovation and Science to work with the Department of Infrastructure and Regional Development to consider ways to harmonise the <i>Disability Standards for Accessible Public Transport 2002</i> (Transport Standards) with the Standards where appropriate (Section 2.7 of the Review Report).	Part H	Supported
1.d. Update the Standards to include any revised emergency egress provisions (including DP7) of the NCC (Section 2.9 of the Review Report).	Part D - DP7	Supported
1.e. Amend clause D3.3(f)(ii) so that the floor area threshold of 200m ² for each storey only applies to the parts of each storey available to occupants and not exempted by clause D3.4.		Supported in Principle
1.f. All new access-related provisions within the NCC be included in the Access Code of the Standards.	Various	Supported in principle
2. Develop guidelines to help stakeholders better appreciate the content and scope of the Standards.	-	Noted: The Australian Government, through the Building Ministers' Forum (BMF) will encourage the state and territory governments to better utilise the Australian Human Rights Commission's (AHRC) detailed guidelines on the application of the Standards, which are available freely online, to help stakeholders better appreciate the content and scope of the Standards. In addition, the BMF should also promote the use of the Australia Building Codes Board's (ABCB) comprehensive free training material on disability access for the building and construction industry and other interested stakeholders.
2.a. Guidance on accessible carparking be developed as part of the development of an updated guideline for the Standards; this may also include reference to AS/NZS 2890.6-2009 (Section 2.6 of the Review Report)	DP1, DP8, D3.5	Noted
2.b. Revise guidance material to provide more clarity on instances where the Standards and the Transport Standards interact and differ and on which structures related to transport buildings are classified as Class 9b or Class 10 (Section 2.7 of the Review Report)	Part H2	Noted
2.c. New guidelines be developed to better explain the requirements of the Standards (Section 4 of the Review Report).	-	Noted
2.d. Develop guidelines to provide greater clarification and understanding of the Standards (Section 5 of the Review Report).	-	Noted

2.e. State and territory building authorities consider ways to improve the transparency of decisions on questions of unjustifiable hardship and accepted alternative solutions (Section 6 of the Review Report).	Part 4.1	Noted
3. Improve education and training to raise awareness and understanding (for example, in relation to improved marketing of accessible accommodation rooms in hotels, and the unjustifiable hardship [exception]) of key issues covered by the Standards.	-	Noted: The Australian Government, through the BMF will encourage the state and territory governments to better utilise the AHRC's published guidelines and promote the use of the ABCB's comprehensive free training material on disability access for the building and construction industry and other interested stakeholders.
3.a. The tourism and accommodation industry in collaboration with the disability sector undertake to improve the marketing of accessible rooms (Section 2.1.2 of the Review Report).	-	Noted
3.b. Further work be undertaken to update data on the economic value of accessible accommodation in Australia (Section 2.1.2 of the Review Report).	-	Noted
3.c. Develop guidance information, including education and training material, to raise awareness across a broad range of stakeholders on the purpose of the unjustifiable hardship [exception] and the role of Access Panels (Section 3.3 of the Review Report).	Part 4.1	Noted
3.d. Improve education and training material available for different stakeholder groups, to raise awareness of issues covered by the Standards (Section 5 of the Review Report).	-	Noted
4. Develop guiding principles for coordinated data collection, analysis and audits and gain the cooperation of responsible organisations (including state and territory governments) to enable monitoring and reporting for future reviews.	-	Supported in Principle: The Australian Government will seek support, in-kind and financial, from the state and territory governments (via the BMF) for the development of a Data Framework which can be used by each jurisdiction to conduct base line studies on the matters set out in 4.a. to 4.c. to inform the next scheduled review of the Standards and beyond. The Data Framework would be established through two projects: • the establishment of an expert working group (consisting of government representatives, building experts, and disability advocates) to articulate the data needs and future reporting requirements; and • the engagement of a business analyst to advise on the survey requirements and core system requirements for conducting the broader baseline study nationally.
4.a. Prior to the next five-year review, research should be undertaken to clarify whether the current ratio [of accessible carpark spaces] is sufficient as a minimum standard or whether consideration needs to be given to changing the ratio (Section 2.6 of the Review Report).	DP1, DP8, D3.5	Supported in Principle
4.b. Consider any new methods for quantifying the benefits of additional emergency egress options (as costs and technologies may change over that time), at the next five-year review (Section 2.9 of the Review Report).	-	Supported in Principle
4.c. Establish processes for the systematic and coordinated collation and analysis of data on implementation of the Standards to improve monitoring and to inform future reviews (Section 6 of the Review Report).	-	Supported in Principle
5. Establish a governance structure to oversee a forward work program. This would involve a governance group comprising the Department of Industry, Innovation and Science, the Attorney-General's Department and the Department of Social Services to oversee the work.	-	Supported in Principle: The governance structure for the Data Framework project set out in Recommendation 4 , through the BMF, would provide an appropriate governance structure that would consult with the Attorney-General's Department and the Department of Social Services on matters where appropriate.

6. Establish expert advisory groups under the governance group as needed to provide technical advice and guidance on relevant matters. Expert advisory groups should include representatives relevant to the work program (such as the ABCB, state and territory building regulators, local government, building and construction organisations, design professionals, access consultants, disability organisations and accommodation and tourism stakeholders). 6.a. Consider whether the conversion of Class 1a buildings to specified Class 1b rooming/boarding houses has been affected by the Standards, the extent of any such effect and, if required, what further actions should be undertaken (Section 2.1.1 of the Review Report).	- A1.1 & D3.1	Supported in Principle: The Australian Government will ask the BMF to prioritise Recommendations 6.a. to 6.t and establish a single expert advisory group to provide advice on those recommendations, noting that not all matters will need expert advice. Supported in Principle
6.b. Investigate whether, and how, accessible adult changing facilities should be included in the Standards (Section 2.2 of the Review Report).	AS1428.1-2009	Supported in Principle
6.c. Consider developing a workable definition of "bank of toilets" and determine whether changes to specifications may be needed. For example, consideration should be given to the impact the definition may have on the requirement for an accessible sanitary facility at 50 per cent of banks of toilets and on the distance between accessible sanitary facilities in large buildings (Section 2.2 of the Review Report).	F2.4	Supported in Principle
6.d. Investigate whether changes to the 80 th and 90 th percentile wheelchair dimensions should be considered (Section 2.3 of the Review Report).	H2.2	Noted
6.e. Consider ways to improve the understanding of accessibility issues in swimming pool design in any updated guideline (Section 2.5 of the Review Report).	D3.1, D3.10 & Part D5	Noted
6.f. Consider whether, and how, accessible adult changing facilities should be included in the Standards as part of the larger body of work regarding accessible adult changing facilities (Section 2.5 of the Review Report).	AS1428.1-2009	Supported in Principle
6.g. Consider the issue of data in relation to carparking permits versus number of accessible car parks (Section 2.6 of the Review Report).	DP1, DP8, D3.5	Supported in Principle
6.h. Consider the specifications with AS/NZS 2890.6-2009 to determine whether there is a need to consider requesting changes to the standard [re: standardising the maximum distance between accessible carparks and position of car parks to building entry points].	AS/NZS 2890.6	Supported in Principle
6.i. Consider an editorial amendment to D3.5d, replacing "designated" with "identified with signage" and clarifying the intended meaning of D3.5d related to signage and shared zones (Section 2.6 of the Review Report).	D3.5(d)	Supported in Principle
6.j. Consider how a "whole-of journey" approach to accessibility planning may be promoted and encouraged through guidance material (Section 2.7 of the Review Report).	Part H2	Noted
6.k. Following finalisation of the new wayfinding standard by Standards Australia, consider options for incorporating the standard in the Standards (Section 2.8 of the Review Report).	Part H3	Supported in Principle

6.I. Consider further information to be included in guidance material to promote the best practice installation of tactile ground surface indicators (Section 2.8 of the Review Report).	D3.6 & Part D4	Supported in Principle
6.m. Consider whether there is a case to amend the exception at F2.4(i) to refer only to wheelchair accessible sanitary facilities and to clarify that ambulant toilet amenities are still required on floors other than the entrance level where appropriate (Section 3.1 of the Review Report).	F2.4	Supported in Principle
6.n. Explore options to revise the lessee concession to provide greater access to ground floor shopfronts where appropriate (Section 3.2 of the Review Report).	Part 4.3	Supported in Principle
6.o. Advise how best to include subdivisions and strata title holders in the Standards (Section 3.2 of the Review Report).	-	Supported in Principle
6.p. Consider a coordinated approach to improving the mechanisms to [provide guidance on the unjustifiable hardship exceptions] (Section 3.3 of the Review Report).	Part 4	Supported in Principle
6.q. Establish an expert advisory group (comprising state and territory building authorities, the [AHRC], the [ACHRA], local government, people with disability and access consultants) to develop guiding principles for Standards measurement requirements for consideration by the Commonwealth. Matters to be considered would include the purpose of collecting and reporting data, what to measure, how to measure, collect and report and who should collect and report data (Section 6 of the Review Report).	-	Supported in Principle
6.r. Consider whether it is necessary to amend the current five-year review cycle for the Standards to fit in with the new publication cycle of the NCC (Section 7 of the Review Report).	Part 6.1	Not Supported
6.s. Consideration [be given to] a workable definition of inbuilt amplification system (Section 7 of the Review Report).	A1.1	Supported in Principle
6.t. If AS 1428.5-2010 is revised and is in a suitable format for inclusion in the Standards and NCC, consider how the standards might be incorporated (Section 7 of the Review Report).	D3.7	Supported
Appendix 7: Proposals for change in the Standards.	-	Supported in principle: The Australian Government will implement 21 of the 30 technical amendments to the Standards set out in Appendix 7 (refer below for details) of the Review Report; support in principle six of the remaining proposed amendments subject to the completion of a RIA; note two recommendations and issue a proposal to Standards Australia to review and update AS 1428.1; and not support the proposed change to clause A2.2 of the Standards. Refer to the response to Recommendation 1.
7.1. Concession for Sanitary Facility Signage - D3.6(a)(i) extend the concession to not provide sanitary facility signage to also apply to soleoccupancy units (SOUs) in Class 9c buildings and remove the reference to Class 1b SOUs.	D3.6(a)(i)	Supported
7.2. Concession for Sanitary Facility Signage - amend D3.10(3) by removing the words "in length".	D3.10(3)	Supported
7.3. Performance Requirements for Access and Egress DP6 - editorial correction replacing "building" with "buildings".	D – DP6	Supported
7.4. Designated Carparking Spaces –an editorial amendment to D3.5(d) to make it clear that where an accessible carpark has fewer than five car parking spaces, signage and markings for the particular accessible carpark is not required.	D3.5(d)	Supported

7.5. Braille and Tactile Signs – Sentence or Title	D4.3(2)	Supported
Case – change the requirement in subclause		
D4.3(2) for tactile characters in signs from		
"sentence case" to "title case".		
7.6. Limitations on the Use of Stairway Platform	Table E3.6a	Supported
Lifts and Lifts for Persons of Limited Mobility -align		
the wording for the limitations on use of lifts in high		
traffic public areas in Table E3.6(a) of the		
Standards with Table E3.6a in the NCC.		
Clamada Will Table 2010a III ille 11001		
7.7. Seating in Class 9b Assembly Buildings –	D3.9(b)(iii) and	Supported
delete subparagraph D3.9(b)(iii) on the basis that it	Table D3.9	
was included in error and causes confusion about	. 6.5.6 2 6.6	
the thresholds for wheelchair seating spaces.		
the thresholds for wheelchair seating spaces.		
7.8. Definition and Application of a Continuous	A1.1 & D3	Supported in Principle
Accessible Path of Travel - Compliance with AS	7111 0 00	Supported III I III office
1428.1.		
7.9. Accessible Sanitary Facilities –provide a	A1.1 & F2.4	Supported in Principle
definition on what constitutes a "bank of toilets".	A1.1 Q12.4	варропеа ил пиногріє
definition on what constitutes a bank of tollets.		
7.10. Toilet Concessions – remove "affected part"	Part 4 - 4.5(2)(b)	Supported
•	alt = 4.0(2)(b)	Supported
from paragraph 4.5(2)(b).	F2 /	Supported in Principle
7.11. : Accessible Sanitary Compartments in Class	4.4	σαρροπού τη Επιτοιρίο
9b Childcare Buildings – remove the requirement for ambulant and accessible toilets to be installed		
at a bank of toilets containing junior pans in a		
Class 9b early childhood centre from clause F2.4.		
7.13 Close 3 buildings Order of Descriptors and	D3 Table D3.1	Supported
7.12. Class 3 buildings – Order of Requirements		Supported
Table D3.1 Class 3 – relocate the requirements for	Class 3 (SOU)	
the location and representative nature of Class 3		
SOUs to follow the requirements for the number of		
accessible SOUs.		
	Do 40 (0)(L)	
7.13. Gradient for Zero Depth Swimming Pool	D3.10 (2)(b)	Supported
Entry – amend paragraph D3.10(2)(b) to remove		
the maximum gradient specified for zero depth		
swimming pool entry.		
7.14. Amend clause A1.1 to update the definition	A1.1	Supported
of "early childhood centre" for consistency with the		
NCC.		
7.15. Amend clause A1.1 so that the definition of	A1.1	Supported
the Building Codes of Australia (BCA) refers to the		
current version of the BCA.		
7.16. Amend clause A1.1 to update the definition	A1.1	Supported
of "swimming pool" for consistency with the		
definition in the BCA.		
7.17. Amend Part D of the Standards to include the	Part D	Supported
performance requirements of set out in DP7 of the		
NCC.		
7.18. Part A1.1 and Tables E3.6(a) and (b) - insert	Part A1.1	Supported
definitions for "electric passenger lift",		
"electrohydraulic passenger lift", "inclined lift", "low-		
rise, low-speed constant pressure lift", "low-rise		
platform lift", 'Small-sized, low-speed automatic lift"		
and "stairway platform lift" and replace the		
reference to the Australian Standards for Lifts		
(excluding AS 1735.12) in Tables E3.6(a) and (b).		
7.19. Signage amend clause D3.6 to reflect	D3.6(a)	Supported
updates to the NCC.		
7.20. A3.1 Table 1 - update the referenced	A3.1 Table 1	Supported
documents and clause references for each		
referenced standard.		
7.21. Amend the definition of a Class 10 building at	A4.1	Supported
clause A4.1 to reflect the inclusion of Class 10c		
private bushfire shelters.		
<u>.</u>	A2.2	Not Supported
the Standards with a similar provision in the BCA.		
The state of the s		
7.23. Swimming Pool Lift Figures – amend Figure	D5 Figure D5.7	Supported
D5.7 to align with Figure 5 BCA Specification		
D3.10.		
-0.10	1	

7.24. Amend references to "Class 9c aged care buildings" to "Class 9c buildings" wherever they occur in the Standards for simplification as all Class 9c buildings are inherently aged care buildings.	Access Code	Supported
7.25. Handrails and Domed Buttons (Tactile Indicators) – in paragraph D3.3(c) change the reference for domed buttons from AS 1428.1 to AS 1428.4.1 and remove reference to "requirements for stairway handrails".		Supported
7.26. Signage – rationalise the sign requirements in Clause D3.6.	D3.6	Supported in Principle
7.27. Carpet Pile Height – Delete paragraphs D3.3(g) and (h) to reflect changes to AS 1428.1.	D3.3(g) and (h)	Supported in Principle
7.28. Accessible Switches and GPOs in SOUs – amend clause 14.2 of AS 1428.1 so it applies only in accessible sanitary facilities and accessible residential SOUs rather than all SOUs.	AS 1428.1	Noted
7.29. Review the requirement for minimum luminance contrast for accessible toilet seats in AS 1428.1.	AS 1428.1	Noted
7.30. Small Building Concession – Calculation of Floor Area – when calculating the floor area of a storey to determine whether the concession for small buildings is applicable, areas currently exempted under clause D3.4 should not be included.	D3.3(f)	Supported in Principle