Annex B

Slimline sliding door RFQ: replies from Australian suppliers (29 October 2026)

A homeowner's supply-and-install RFQ for a house in Victoria, sent to 20 Australian window and door suppliers on 29 October 2026. Seven replied. Referred to in Part B.3.

Contents: (1) Trend Windows reply, 29 October 2026; (2) Triple E Windows & Doors reply, 29 October 2026; (3) the RFQ (redacted transcript).

Redactions: the requester's identity, the project address, recipients, finish colour and personal contact details. The replies are otherwise reproduced as received.

Response to SEF 691 by Ellie Vaisman, Procon Materials Pty Ltd. Non-confidential.

Trend - InfoLeads - VIC <infoleadsvic@trendwindows.com.au> Thu, Oct 29, 2026 at 2:17 PM
To [redacted]


Good Afternoon,

Trend is a manufacturing company. Trend do not install.

Trend will not be quoting this project.

All the best

Trend Windows and Doors Pty Limited
trendwindows.com.au



Annex B - Triple E Windows & Doors reply, 29 October 2026 (redacted)

[redacted]

We have identified a sizing constraint with the proposed sliding door in relation to the requirements of the energy report.

The specified performance is **U-Value 2.32 / SHGC 0.31**, which can be achieved with a thermally broken sliding door system. However, this system is limited to approximately **3.0 m high x 4.0 m wide doors**, while the scheduled door is **3.5 m high x 4.6 m wide**.

The **ProGlide Minimalist Sliding Door** can accommodate the **3.5 m height**, but with a maximum width of **3.6 m**. Its achievable performance is approximately **U-Value 2.8 / SHGC 0.31**, so both the window schedule and U-Value requirement would need to be considered.

Please give us a call tomorrow for a brief discussion so we can review the options and determine the best way forward.

Thanking you,

Kind Regards

[redacted]
Senior Estimator

TRIPLE E
WINDOWS & DOORS

www.tripleewindows.com.au
35 Industrial Circuit Cranbourne West 3977
1300 003 515
[redacted]
Office: (03) 9769 9226