

APPENDIX 1

NMI 14/2/151

Rev 2

12/08/13



Australian Government
National Measurement Institute

Pattern Approval Number: 14/2/151

Manufacturer/Make: EDM I

Model	Type of meter	Connection / operation	Accuracy class	Phases	Wires	Reference frequency	Reference voltage	Rated or Basic current	Maximum current	Meter constant
MK2, Mark 2	Electronic	Transformer-operated	0.2	3	3, 4	50 Hz	3x63.5/110 V AC	1 A, 5 A	2 A, 10 A	Programmable
MK3	Electronic	Transformer-operated	0.2	3	3, 4	50 Hz	57-240 V AC	1 A, 5 A	4 A, 20 A	1 Wh/imp ^[1]
MK3	Electronic	Transformer-operated	0.5	3	3, 4	50 Hz	57-240 V AC	1 A, 5 A	4 A, 20 A	1 Wh/imp ^[1]
MK6	Electronic	Transformer-operated	0.5	3	4	50 Hz	57-120 V AC, 57-240 V AC	1 A, 5 A	4 A, 20 A	1 Wh/imp
MK6	Electronic	Direct-connected	0.5	3	4	50 Hz	57-240 V AC	10 A	100 A	1 Wh/imp
MK6N	Electronic	Transformer-operated	0.5	3	4	50 Hz	57-120 V AC, 200-240 V AC	1 A, 5 A	4 A, 20 A	1 Wh/imp ^[1]

Note [1]: Other values may be applicable.