

APPENDIX 1

NMI 14/2/152

Rev 1

10/05/13



Australian Government
National Measurement Institute

Pattern Approval Number: 14/2/152

Manufacturer/Make: Elster

Model	Type of meter	Connection / operation	Accuracy class	Phases	Wires	Reference frequency	Reference voltage	Rated or Basic current	Maximum current	Meter constant
A1100	Electronic	Direct-connected	1	3	4	50 Hz	240/415 V AC	10 A	100 A	1000 imp/kWh
A1800	Electronic	Direct-connected	1	3	4	50 Hz	240/415 V AC	5 A	120 A	500 imp/kWh
A1800	Electronic	Transformer-Operated	1	3	4	50 Hz	240/415 V AC	5 A	15 A	2500 imp/kWh