

APPENDIX 1

NMI 14/2/153

Rev 1

12/07/13



Australian Government
National Measurement Institute

Pattern Approval Number: 14/2/153

Manufacturer: Email, Ampy, Ampy Metering

Model	Type of meter	Connection / operation	Accuracy class	Phases	Wires	Reference frequency	Reference voltage	Rated or Basic current	Maximum current	Meter constant
EM3030	Electronic	Direct-connected	1	3	4	50 Hz	3 × 240/415 VAC	10 A	125 A	1 Wh/imp
EM3330, EM3332	Electronic	Direct-connected	1	3	4	50 Hz	3 × 240/415 VAC	10 A	125 A	1 Wh/imp
EM3130	Electronic	Direct-connected	1	3	4	50 Hz	3 × 240/415 VAC	10 A	125 A	1 Wh/imp
EM3350	Electronic	Transformer-operated	1	3	4	50 Hz	3 × 240/415 VAC	5 A	20 A	1 Wh/imp
EM5100	Electronic	Direct-connected	1	3	4	50 Hz	3 × 240/415 VAC	10 A	125 A	1 Wh/imp
EM5300	Electronic	Transformer-operated	0.2 or 0.5	3	4	50 Hz	3 × 240/415 VAC	1 A, 5 A	10 A, 20 A	Adjustable
EM5312	Electronic	Transformer-operated	0.2	3	3 or 4	50 Hz	63.5, 110, or 240 V AC	1 A	6 A	0.1 Wh/imp
EM5315	Electronic	Transformer-operated	0.5	3	3 or 4	50 Hz	63.5, 110, or 240 V AC	1 A	10 A	0.1 Wh/imp
Q4	Electronic	Transformer-operated	0.5	3	3 or 4	50 Hz	63.5, 110, or 240 V AC	1 A, 5 A	3 A, 15 A	Adjustable
Q4	Electronic	Direct-connected	1	3	4	50 Hz	3 x 240 VAC	10 A	100 A	1 Wh/imp
Q4A	Electronic	Direct-connected	1	3	4	50 Hz	3 x 240 VAC	10 A	100 A	Adjustable
Q4W	Electronic	Direct-connected	1	3	4	50 Hz	3 × 240/415 VAC	10 A	100 A, 125 A	1 Wh/imp
Q4W	Electronic	Transformer-operated	0.5	3	4	50 Hz	3 × 240/415 VAC	5 A	15 A	4 Wh/imp
P1	Electronic	Direct-connected	1	1	2	50 Hz	240 V AC	15 A	100 A	10 Wh/imp
A11L	Electronic	Direct-connected	1	1	2	50 Hz	240 V AC	10 A	100 A	Adjustable