

APPENDIX 1

NMI 14/2/158

Rev 0

8/03/13



Australian Government
National Measurement Institute

Pattern Approval Number: NMI 14/2/158
Manufacturer/Make: Dore Electrics

Model	Type of meter	Connection / operation	Accuracy class	Phases	Wires	Reference frequency	Reference voltage	Rated or Basic current	Maximum current	Meter constant
SPKWH100 or SPKWH100D	Electronic	Direct-connected	0.5	1	2	50 Hz	240 V AC	20 A	100 A	800 imp/kWh
TPKWH5CTD	Electronic	Transformer-operated	0.5	3	4	50 Hz	415 V AC	5 A	- [1]	3600 imp/kWh
TPKWH80	Electronic	Transformer-operated	0.5	3	4	50 Hz	415 V AC	20 A	80 A	160 imp/kWh
TPKWH100 or TPKWH100D	Electronic	Direct-connected	0.5	3	4	50 Hz	415 V AC	20 A	100 A	160 imp/kWh
SPKWH65	Electronic	Direct-connected	1	1	2	50 Hz	240 V AC	10 A	65 A	1000 imp/kWh
SPKWH80	Electronic	Direct-connected	0.5	1	2	50 Hz	240 V AC	20 A	80 A	800 imp/kWh

Note [1]: Values are not specified. Various values may be applicable.