

APPENDIX 1

NMI 14/2/159

Rev 1

12/08/13



Australian Government
National Measurement Institute

Pattern Approval Number: NMI 14/2/159

Manufacturer: Zhejiang Yongtailong Electronic Co Ltd

Brand/Make: K-Mac Powerheads, Patron Power, Smart Building Services or other

Model	Type of meter	Connection / operation	Accuracy class	Phases	Wires	Reference frequency	Reference voltage	Rated or Basic current	Maximum current	Meter constant
DDS-1Y	Electronic, Electro Mechanical	Direct-connected	1	1	2	50 Hz	230-240 VAC	5 A, 10 A	45 A, 50 A, 100 A	Adjustable
DTS353, DTS-353	Electronic	Direct-connected	1	3	4	50 Hz	3x230/400 VAC, 3x240/415 VAC	5 A, 10 A	45 A, 50 A, 150 A	800 imp/kWh
DTS-353-CT, DTS-353	Electronic	Transformer-operated	1	3	4	50 Hz	3x230/400 VAC, 3x240/415 VAC	1.5 A	5 A, 6 A	1200 imp/kWh