

APPENDIX 1

NMI 14/2/163

Rev 0

8/03/13



Australian Government
National Measurement Institute

Pattern Approval Number: NMI 14/2/163

Manufacturer/Make: Itron

Model	Type of meter	Connection / operation	Accuracy class	Phases	Wires	Reference frequency	Reference voltage	Rated or Basic current	Maximum current	Meter constant
ACE 6000	Electronic	Transformer-operated	1	3	4	50 Hz	3x230/400 V AC	1 A	10 A	10,000 imp/kWh
	Electronic	Direct-connected	1	3	4	50 Hz	3x230/400 V AC	10 A	100 A	1000 imp/kWh
ACE 3000	Electronic	Direct-connected	1	3	4	50 Hz	3x230/400 V AC	10 A	100 A	1000 imp/kWh