

APPENDIX 1

NMI 14/2/168

Rev 1

12/07/13



Australian Government
National Measurement Institute

Pattern Approval Number: 14/2/168

Manufacturer/Make: Formway Metering

Model	Type of meter	Connection / operation	Accuracy class	Phases	Wires	Reference frequency	Reference voltage	Rated or Basic current	Maximum current	Meter constant
Iskra ME162-d3A44-KO	Electro-mechanical	Direct-connected	1	1	2	50 Hz	230 V AC	10 A	100 A	1000 imp/kWh
Holley DDS28	Electronic	Direct-connected	1	1	2	50 Hz	230 V AC	10 A	100 A	1000 imp/kWh
Holley DTS541	Electronic	Direct-connected	1	3	4	50 Hz	3x230/400 V AC	10 A	120 A	1000 imp/kWh
Holley DTS541	Electronic	Transformer-Operated	1	3	4	50 Hz	3x230/400 V AC	1 A	5 A	10,000 imp/kWh