

APPENDIX 1

NMI 14/2/169

Rev 0

1/03/13



Australian Government
National Measurement Institute

Pattern Approval Number: NMI 14/2/169

Manufacturer/Make: DM Metering

Model	Type of meter	Connection / operation	Accuracy class	Phases	Wires	Reference frequency	Reference voltage	Rated or Basic current	Maximum current	Meter constant
PRO1TE V11.312	Electro Mechanical	Direct-connected	1	1	4	50 Hz	230 VAC	5 A	45 A	2000 imp/kWh
PRO-75D	Electro Mechanical	Direct-connected	1	1	4	50 Hz	230 VAC	10 A	100 A	1600 imp/kWh
PRO-1250A	Electro Mechanical	Direct-connected	1	3	12	50 Hz	3x230/400 VAC	10 A	100 A	400 imp/kWh
PRO-1250A-CT	Electro Mechanical	Transformer-operated	1	3	12	50 Hz	3x230/400 VAC	1.5 A	6 A	1600 imp/kWh