

APPENDIX 1

NMI 14/2/173

Rev 0

18/06/13

**Australian Government****National Measurement Institute****Pattern Approval Number:** NMI 14/2/173**Manufacturer:** LANX Australia

Model	Type of meter	Connection / operation	Accuracy class	Phases	Wires	Reference frequency	Reference voltage	Rated or Basic current	Maximum current	Meter constant
LXEM145	Electronic	Direct-connected	1	1	2	50 Hz	240 VAC	5 A	45 A	2000 imp/kWh
DDRS202D	Electronic	Direct-connected	1	1	2	50 Hz	230 VAC	10 A	100 A	1600 imp/kWh