

## APPENDIX 1

NMI 14/2/175

Rev 0

20/06/13



**Australian Government**  
**National Measurement Institute**

Pattern Approval Number: NMI 14/2/175

Manufacturer/Make: Zhuhai Pilot

Model	Type of meter	Connection / operation	Accuracy class	Phases	Wires	Reference frequency	Reference voltage	Rated or Basic current	Maximum current	Meter constant
PMAC 735	Electronic	Transformer-operated	1	3	4	50 Hz	3x240/415 V AC	- [1]	5 A	- [2]
PMAC 735	Electronic	Transformer-operated	0.5	3	3, 4	50 Hz	220 - 380 V AC	0.1 A	6 A	Adjustable
PMAC 901	Electronic	Direct-connected	0.5	1	2	50 Hz	198 - 252 V AC	0.5 A	100 A	1000 imp/kWh
PMAC 903	Electronic	Direct-connected	0.5	3	4	50 Hz	198 - 252 V AC	0.5 A	100 A	200 imp/kWh
PMAC 903	Electronic	Transformer-operated	0.5	3	4	50 Hz	198 - 252 V AC	0.1 A	6 A	3600 imp/kWh
PMAC 905	Electronic	Transformer-operated	0.5	3	3, 4	50 Hz	120 - 277 V AC	0.1 A	6 A	Adjustable

Note [1]: Values are not specified. Various values may be applicable.

Note [2]: The meter constant is not applicable. The meter may not have a test output.