



Australian Government

National Measurement
Institute

Bradfield Road, West Lindfield NSW 2070

Certificate of Approval

NMI 14/2/63

Issued by the Chief Metrologist under Regulation 60
of the
National Measurement Regulations 1999

This is to certify that an approval for use for trade has been granted in respect of the instruments herein described.

Landis+Gyr Model EM5300 Class 0.5 Electricity Meter

submitted by Landis+Gyr
60 O’Riordan Street
Alexandria NSW 2015

NOTE: This Certificate relates to the suitability of the pattern of the instrument for use as a legal measuring instrument only in respect of its metrological characteristics. This Certificate does not constitute or imply any guarantee of compliance by the manufacturer or any other person with any requirements regarding safety.

This approval has been granted with reference to document NMI M 6-1 *Electricity Meters. Part 1: Metrological and Technical Requirements*, July 2012.

This approval becomes subject to review on 1/04/18, and then every 5 years thereafter.

DOCUMENT HISTORY

Rev	Reason/Details	Date
0	Pattern & variant 1 approved – certificate issued	28/03/13
1	Pattern amended – variant 2 approved – certificate issued	31/01/14

CONDITIONS OF APPROVAL

General

Instruments purporting to comply with this approval shall be marked with pattern approval number ‘NMI 14/2/63’ and only by persons authorised by the submitter.

It is the submitter's responsibility to ensure that all instruments marked with this approval number are constructed as described in the documentation lodged with the National Measurement Institute (NMI) and with the relevant Certificate of Approval and Technical Schedule. Failure to comply with this Condition may attract penalties under Section 19B of the National Measurement Act and may result in cancellation or withdrawal of the approval, in accordance with document NMI P 106.

Auxiliary devices used with this instrument shall comply with the requirements of General Supplementary Certificate No S1/0B.

Signed by a person authorised by the Chief Metrologist to exercise their powers under Regulation 60 of the *National Measurement Regulations 1999*.

A handwritten signature in black ink, appearing to read 'Dr A Rawlinson', with a horizontal line underneath.

Dr A Rawlinson

TECHNICAL SCHEDULE No 14/2/63

1. Description of Pattern **approved on 28/03/13**

A Landis+Gyr model EM5300 Class 0.5 electronic polyphase current transformer (CT) operated static watt hour meter (Figure 1) used to measure electrical energy.

1.1 Field of Operation

The field of operation of the measuring system is determined by the following characteristics:

- Number of phases 3
- Number of wires 3 or 4
- Reference frequency 50 Hz
- Reference ambient temperature ranges:
 - specified range of operation -10 to 60°C
 - limit range of operation -20 to 70°C
- Rated voltage 3 × 240 (415) V AC
- Rated currents: Rated current, I_n 1 A
Maximum current, I_{max} 10 A
- Meter constant 0.1 Wh/imp
- Accuracy class 0.5

1.2 Features/Functions

- Three (3) elements
- Electronic (LCD) digital indicator
- Panel mount type housing
- Internal crystal-controlled and/or synchronous clocks

1.3 Verification Provision

Provision is made for the application of a verification mark.

1.4 Descriptive Markings and Notices

Instruments are marked with the following data, together in one location, in the form shown at right:

Manufacturer's name or mark	...
Model designation	...
Serial number	...
Pattern approval mark	NMI 14/2/63
Number of phases	...
Number of wires	...
Reference frequency	... Hz
Meter constant	...
Rated voltage	... AC
Rated currents:	I_n ... A
	I_{max} ... A
Accuracy index	Class 0.5

FIGURE 14/2/63 – 1



Landis+Gyr Model EM5300 Class 0.5 Electricity Meter
(Including Typical Mechanical Sealing)