

Australian Government

Department of Industry, Science and Resources

National Measurement Institute

36 Bradfield Road, West Lindfield NSW 2070

# Certificate of Approval NMI 14/2/98

Issued by the Chief Metrologist under Regulation 60 of the National Measurement Regulations 1999

This is to certify that an approval for use for trade has been granted in respect of the instruments herein described.

CET ELECTRIC TECHNOLOGY INC. model CET PMC-220-C35AE Electricity Meter

submitted by CETA Australia Pty Ltd 2/40 Douglas Street Milton QLD 4064

**NOTE:** This Certificate relates to the suitability of the pattern of the instrument for use for trade only in respect of its metrological characteristics. This Certificate does not constitute or imply any guarantee of compliance by the manufacturer or any other person with any requirements regarding safety.

This approval has been granted with reference to the document NMI M 6-1, *Active-energy electricity meters (a.c.) Part 1: Metrological and technical requirements*, June 2022.

This approval is subject to review at the decision of the Chief Metrologist in accordance with the conditions specified in the document NMI P 106.

Rev	Reason/Details	Date		
0	Pattern approved – certificate issued			
1	Pattern and variant 1 (Change of model name) approved – certificate issued	13/07/17		
2	Pattern (Include measurement in both directions) approved – certificate issued			
3	Variant 2 approved – certificate issued	05/07/23		

## DOCUMENT HISTORY

#### CONDITIONS OF APPROVAL

#### General

Instruments purporting to comply with this approval shall be marked with approval number 'NMI 14/2/98' and only by persons authorised by the submittor.

It is the submittor's responsibility to ensure that all instruments marked with this approval number are constructed as described in the documentation lodged with the National Measurement Institute (NMI) and with the relevant Certificate of Approval and Technical Schedule. Failure to comply with this Condition may attract penalties under Section 19B of the National Measurement Act and may result in cancellation or withdrawal of the approval, in accordance with document NMI P 106.

Signed by a person authorised by the Chief Metrologist to exercise their powers under Regulation 60 of the *National Measurement Regulations 1999*.

**Darryl Hines** Manager Policy and Regulatory Services

## TECHNICAL SCHEDULE No 14/2/98

## 1. Description of Pattern

## approved on 9/01/17

A CET ELECTRIC TECHNOLOGY INC. model CET PMC-220-C35AE single phase class 1 direct connected static watt hour meter (Figure 1) used to measure electrical energy.

## 1.1 Field of Operation

The field of operation of the measuring system is determined by the following characteristics:

Number of phases	1				
<ul> <li>Number of wires</li> </ul>	2				
Reference frequen	50 Hz				
Reference ambient temperature ranges:					
specified ra	specified range of operation				
limit range o	−25 to 70 °C				
<ul> <li>Rated voltage</li> </ul>		95 to 240 V AC			
<ul> <li>Rated currents:</li> </ul>	Basic current, $I_{h}$	5 A			
	Maximum current, I <sub>max</sub>	63 A			
<ul> <li>Meter constant</li> </ul>		1000 imp/kWh			
<ul> <li>Accuracy class</li> </ul>		1			

## 1.2 Features/Functions

- Liquid crystal digital indicator having a maximum display of 999999.9 kWh
- DIN-rail mounting
- Measurement in both positive and negative directions

Note: The pattern is NOT fitted with an internal clock.

## **1.3 Verification Provision**

Provision is made for the application of a verification mark.

## 1.4 Sealing Provision

Provision is made for the calibration adjustments to be sealed by the application of a mechanical seal (Figure 1).

## 1.5 Descriptive Markings

Instruments are marked with the following data, together in one location:

Manufacturer's mark, or name written in full	
Model designation	
Serial number	
Pattern approval mark	NMI 14/2/98
Number of phases	
Number or wires	
Reference frequency	Hz
Temperature limits (if other than -10 to 60₀C)	to °C
Meter constant	
Rated voltage	AC
Rated currents:	I <sub>b</sub> A
	I <sub>max</sub> A
Accuracy class	

#### 1.6 Harmonics

Instruments purporting to comply with this approval are suitable for use where the harmonics do not exceed those specified in NMI M 6-1:2022.

## 2. Description of Variant 1

#### approved on 13/07/17

This meter is also known as model IPD -163C. Please see the corresponding labels for IPD-163C (Figures 14/2/98 - 3 and 14/2/98 - 4).

## 3. Description of Variant 2

This meter is also known as MATelec branded - model FKW-11000-1. Please see the corresponding image in Figure 14/2/98 - 5.

## TEST PROCEDURE No 14/2/98

Instruments tested for initial verification shall comply with the certificate of approval and technical schedule, and the maximum permissible errors for verifications at the operating conditions in effect at the time of verification.

Meters shall be verified in accordance with NITP 14 National Instrument Test Procedures for Utility Meters.

NOTE: NMI reserves the right to vary this procedure. Any such variation shall be notified in writing by NMI.

# approved on 05/07/23

## FIGURE 14/2/98 - 1



CET ELECTRIC TECHNOLOGY INC. model CET PMC-220-C35AE Electricity Meter Including Typical Mechanical Sealing

## FIGURE 14/2/98 - 2



CET ELECTRIC TECHNOLOGY INC. model CET PMC-220-C35AE Electricity Meter Showing Markings FIGURE 14/2/98 – 3

(ipd 🤇			
Un: Ib: Imax: Ist: Freq: NMI: For Indoo	IPD163C 95-240VAC, 0 5A 63A 20mA 45Hz-65Hz 14/2/98 or Use Only	Roboto	Condensed, 5pt

Variant 1 - CET ELECTRIC TECHNOLOGY INC. model IPD 163C Electricity Meter



FIGURE 14/2/98 – 4

Variant 1 - CET ELECTRIC TECHNOLOGY INC. model IPD 163C Electricity Meter

## FIGURE 14/2/98 - 5



Variant 2 - MATelec branded - model FKW-11000-1 Electricity Meter

~ End of Document ~