



Australian Government

Department of Industry,  
Science and Resources

**National  
Measurement  
Institute**

36 Bradfield Road, West Lindfield NSW 2070

**Certificate of Approval**  
**NMI 14/2/122**

Issued by the Chief Metrologist under Regulation 60  
of the  
*National Measurement Regulations 1999*

This is to certify that an approval for use for trade has been granted in respect of the instruments herein described.

Secure Meters Limited model Premier 550 (S3E551) three phase Class 0.5 S  
Electricity Meter

submitted by      Secure Meters (Australia) Pty Ltd  
39-41 Fennel Street  
Port Melbourne VIC 3207

**NOTE:** This Certificate relates to the suitability of the pattern of the instrument for use for trade only in respect of its metrological characteristics. This Certificate does not constitute or imply any guarantee of compliance by the manufacturer or any other person with any requirements regarding safety.

This approval has been granted with reference to document NMI M 13-1 *Active-energy electricity meters (a.c.), Part 1: Metrological and Technical Requirements*, dated June 2022.

This approval is subject to review at the decision of the Chief Metrologist in accordance with the conditions specified in the document NMI P 106.

DOCUMENT HISTORY

Rev	Reason/Details	Date
0	Pattern & Variants 1 & 2 approved – certificate issued	15/08/25


## CONDITIONS OF APPROVAL

### General

Instruments purporting to comply with this approval shall be marked with approval number 'NMI 14/2/122' and only by persons authorised by the submitter.

It is the submitter's responsibility to ensure that all instruments marked with this approval number are constructed as described in the documentation lodged with the National Measurement Institute (NMI) and with the relevant Certificate of Approval and Technical Schedule. Failure to comply with this Condition may attract penalties under Section 19B of the National Measurement Act and may result in cancellation or withdrawal of the approval, in accordance with document NMI P 106.

Signed by a person authorised by the Chief Metrologist  
to exercise their powers under Regulation 60 of the  
*National Measurement Regulations 1999*.

A handwritten signature in black ink, appearing to read 'Phillip Mitchell', is positioned above the printed name and title.

**Phillip Mitchell**  
Acting Manager  
Policy and Regulatory Services

## TECHNICAL SCHEDULE No 14/2/122

### 1. Description of Pattern

approved on 15/08/25

A Secure Meters Limited model Premier 550 (S3E551) three phase Class 0.5 S transformer operated static watt hour meter (Figure 1) used to measure active electrical energy.

#### 1.1 Field of Operation

The field of operation of the measuring system is determined by the following characteristics:

- |                              |   |
|------------------------------|---|
| • Number of phases           | 3   |
| • Number of wires            | 3 or 4  |
| • Reference frequency        | 50 Hz   |
| • Reference temperature      | 27 °C   |
| • Reference voltage          | 2 × 100 to 110 V AC (3P3W) or<br>3 × 57.7/100 V AC to<br>3 × 63.5/110 V AC (3P4W) |
| • Rated current, $I_n$       | 1 or 5 A  |
| • Maximum current, $I_{max}$ | 10 A  |
| • Meter constant             | 38400 imp/kWh   |
| • Accuracy class             | 0.5 S   |

#### 1.2 Features/Functions

- Liquid crystal digital indicator having a maximum display of 99999.999 kWh
- Internal synchronous and crystal clocks
- Measurement in both positive and negative directions (import and export)
- Optical port
- Wired communications

#### 1.3 Verification Provision

Provision is made for the application of a verification mark.

#### 1.4 Sealing Provision

Provision is made for the sealing devices and parameters that have a metrologically significant effect and that determine the measurement result by the application of mechanical seals and solid state sealing.

## 1.5 Descriptive Markings

Instruments are clearly and permanently marked with the following data, in the vicinity of the indicating device, in the form shown right:

Instruments are clearly and permanently marked with the following data, visible following installation, in the form shown right:

Manufacturer's mark, or name written in full	.....
Model designation	.....
Serial number	.....
Pattern approval mark	NMI 14/2/122
Number of phases	.....
Number of wires	.....
Reference frequency	..... Hz
Reference temperature (if different from 23 °C)	..... °C
Transformer ratios	.....
Meter constant	.....
Reference voltage	..... AC
Rated currents	$I_n$ ..... A $I_{max}$ ..... A
Accuracy class	.....
Environment	Indoor meter or IM

The meter constant, reference voltage and rated currents are viewed via the display. The relevant procedure to access this information is included in the operator's manual (Figure 2).

## 1.6 Harmonics

Instruments purporting to comply with this approval are suitable for use where the harmonics do not exceed those specified in AS 62053.22 (2018).

## 2. Description of Variant 1 approved on 15/08/25

A Secure Meters Limited model Premier 550 (S3T551) three phase Class 0.5 S transformer operated static watt hour meter (Figure 3) used to measure active electrical energy. This variant has the same field of operation, features and functions as the pattern with the exception of the following:

- Reference voltage  $3 \times 230/400$  V AC (3P4W)
- Meter constant 12800 imp/kWh

## 3. Description of Variant 2 approved on 15/08/25

The pattern and variants are approved with an additional 'Skyline-i 045' communication module supporting 4G/2G communications and an alternative terminal cover (Figure 3).

## TEST PROCEDURE No 14/2/122

Instruments tested for verification shall comply with the certificate of approval and technical schedule, and the maximum permissible errors for verifications at the operating conditions in effect at the time of verification.

The maximum permissible errors are specified in the *National Trade Measurement Regulations 2009* (Cth).

Electricity meters shall be verified in accordance with the following National Instrument Test Procedures:

- NITP 14.0 – Utility Meters – general requirements
- NITP 14.2 – Utility Meters – electricity meters


NOTE: NMI reserves the right to vary this procedure. Any such variation shall be notified in writing by NMI.

FIGURE 14/2/122 – 1



Secure Meters Limited model Premier 550 (S3E551) (the Pattern)

FIGURE 14/2/122 – 2



Instructions to access relevant information via the display

FIGURE 14/2/122- 3



Secure Meters Limited model Premier 550 (S3T551) (Variant 1) with Skyline  
'Skyline-i 045' communication module (Variant 2)

~ End of Document ~