



Australian Government
Department of Industry,
Science and Resources

**National
Measurement
Institute**

36 Bradfield Road, West Lindfield NSW 2070

Certificate of Approval
NMI 14/3/52

Issued by the Chief Metrologist under Regulation 60
of the
National Measurement Regulations 1999

This is to certify that an approval for use for trade has been granted in respect of the instruments herein described.

Elster Q4000 Electromagnetic model water meter

submitted by Elster Metering Pty Ltd
55 Northcorp Boulevard
Broadmeadows VIC 3047

NOTE: This Certificate relates to the suitability of the pattern of the instrument for use for trade only in respect of its metrological characteristics. This Certificate does not constitute or imply any guarantee of compliance by the manufacturer or any other person with any requirements regarding safety.

This approval has been granted with reference to document NMI R 49-1 Water Meters Intended for the Metering of Cold Potable Water and Hot Water, *Part 1 Metrological and Technical Requirements*, dated May 2022 and NMI M 10-1 Meters Intended for the Metering of Water in Full Flowing Pipes, *Part 1: Metrological and Technical Requirements*, dated July 2010.

This approval is subject to review at the decision of the Chief Metrologist in accordance with the conditions specified in the document NMI P 106.

DOCUMENT HISTORY

Rev	Reason/Details	Date
0	Pattern & variants 1 to 3 approved – certificate issued	22/07/20
1	Variants 4 & 5 approved – certificate issued	01/08/25


CONDITIONS OF APPROVAL

General

Instruments purporting to comply with this approval shall be marked with pattern approval number 'NMI 14/3/52' and only by persons authorised by the submitter.

It is the submitter's responsibility to ensure that all instruments marked with this approval number are constructed as described in the documentation lodged with the National Measurement Institute (NMI) and with the relevant Certificate of Approval and Technical Schedule. Failure to comply with this condition may attract penalties under Section 19B of the National Measurement Act and may result in cancellation or withdrawal of the approval, in accordance with document NMI P 106.

Signed by a person authorised by the Chief Metrologist
to exercise their powers under Regulation 60 of the
National Measurement Regulations 1999.

A handwritten signature in black ink, appearing to read 'Phillip Mitchell', written in a cursive style.

Phillip Mitchell
Acting Manager
Policy and Regulatory Services

TECHNICAL SCHEDULE No 14/3/52

1. Description of Pattern

approved on 22/07/20

A DN50 sized Elster Q4000 Electromagnetic model water meter used to measure cold water supplies for trade.

1.1 Field of Operation

The field of operation of the measuring system using the DN50 sized Elster Q4000 Electromagnetic model water meter is determined by the following characteristics:

Minimum flow rate, Q_1 :	0.20 m ³ /h
Transition flow rate, Q_2 :	0.32 m ³ /h
Maximum continuous flow rate, Q_3 :	63.0 m ³ /h
Overload flow rate, Q_4 :	78.75 m ³ /h
Flow rate ratio, Q_3/Q_1 :	315
Temperature class:	T30
Maximum admissible temperature:	30 °C
Limiting condition (water temperature):	50 °C
Maximum admissible pressure:	1600 kPa
Pressure loss class:	Δp 10
Accuracy class:	2
Flow profile sensitivity class:	U10/D2
Electromagnetic class:	E1 or E2 (industrial)
Environmental class:	B or O (indoor & outdoor)
Orientation:	Horizontal
Flow Direction:	Forward
Power supply:	Non-replaceable battery 3.6 V

1.2 Features/Functions

The pattern (Figure 1) consists of an electromagnetic flow sensor and indicating flow computer (calculator/indicator) and has features/functions as listed below:

- Connection type: Wafer type and flange adaptor (Figure 2)
- Display: A digital, electronic, liquid crystal display allowing for a maximum indication range of 999,999 m³ in 0.001 m³ increments (Figure 3)
- Materials: Flow sensor: Stainless steel
Flow converter: Polymer material
- Meter length: 122 mm (meter only)
200 mm (including flange adaptor)

1.3 Conditions

1.3.1 Installation Conditions:

No flow straightener or flow conditioner is required.

For Accuracy Class 2, the flow profile sensitivity class is U10/D2.

For Accuracy Class 2.5, the installation conditions are specified in Table 1.

Table 1 – Minimum pipe lengths required by flow disturbance type

Disturbance Type ⁽¹⁾	Minimum upstream pipe length (mm) ⁽²⁾	Minimum downstream pipe length (mm)
1	10 x DN	2 x DN
2	10 x DN	2 x DN
3	10 x DN	2 x DN

(1) For information on the different types of flow disturbances which are examined as part of pattern approval, refer to NMI M 10-2.

(2) DN (Nominal Diameter) is the alphanumeric designation of size for components of a pipework system, including water meters. It comprises the letters DN followed by a dimensionless whole number that is directly related to the physical size, in millimetres (mm), of the bore or outside diameter of the end connections.

1.3.2 Specified Installations and Open Channel Emplacements [Class 2.5 only]

The meter (pattern and variants) has not been tested or evaluated for performance in specified installations or open channel emplacements as part of this approval.

More information regarding specified installation and open channel emplacement testing may be found in NMI M 10-1 and NMI M 10-2.

1.3.3 Water Quality

The meter is approved for use in the metering of potable water supplies.

The meter is approved for use in the metering of non-potable water supplies of an unspecified nature.

1.4 Software Version

The pattern is approved for use with software versions:

- P 236-1.00.

1.5 Verification Provision

Provision is made for the application of a verification mark.

1.6 Sealing Provision

The register is secured by a one-way snap-on polymer shroud, which cannot be removed without damage. The inner liner, and flow sensors are secured by welded housing ends. Refer to Figure 4 for sealing details.

1.7 Descriptive Markings and Notices

Instruments are marked with the following data, either grouped or distributed on the casing, the indicating device dial or an identification plate (Figure 5):

Manufacturer's name or mark	...
Serial number	...
Pattern approval number	NMI 14/3/52
Numerical value of maximum continuous flow rate, Q_3 ...	
Flow rate ratio, Q_3/Q_1	...
Unit of measurement	m^3
Temperature class ⁽¹⁾	T30
Maximum admissible pressure ⁽²⁾	1600 kPa
Pressure loss class ⁽³⁾	10 kPa or Δp 10
Orientation ⁽⁴⁾	H
Flow profile sensitive class ⁽⁵⁾	U10/D2
Direction of flow	→ or similar
Accuracy class ⁽⁶⁾	2 or 2.5

⁽¹⁾ Optional for Class T30

⁽²⁾ Optional for meters with MAP of 1400 kPa or 600 kPa for $DN \geq 500$

⁽³⁾ Optional for Class Δp 63

⁽⁴⁾ Optional for meters approved for all orientations

⁽⁵⁾ Optional for U0/D0 meters

⁽⁶⁾ Optional for class 2 meters

For instruments that incorporate electronic devices, the following information can either be physically marked on the instrument or provided electronically via the indicating device or similar means:

Electromagnetic class	E1 or E2
Environmental class	B or O
For meters with an external power supply	the voltage and frequency
For battery powered meters	a replacement date or similar indication of expected battery life

2. Description of Variant 1

approved on 22/07/20

The Pattern and Variants are approved with Accuracy class 2.5 (in accordance with NMI M 10-1).

3. Description of Variant 2

approved on 22/07/20

The Pattern and Variants are approved with an alternative replaceable battery, with a model designation of Elster Q4000B Electromagnetic model water meter (Figure 6).

4. Description of Variant 3

approved on 22/07/20

The Pattern and Variants are approved with a range of different sizes, flowrates and associated characteristics as specified in Tables 2 and 3 below. The Pattern is shown in **Bold** for completeness.

Table 2 – Meter sizes, flowrates and related information

Meter size	DN50	DN65	DN80	DN100
Minimum flowrate Q_1 (m ³ /h)	0.20	0.32	0.50	0.79
Transitional flowrate Q_2 (m ³ /h) (*)	0.32	0.50	0.81	1.27
Maximum continuous flowrate Q_3 (m ³ /h)	63.00	100.00	160.00	250.00
Overload flowrate Q_4 (m ³ /h)	78.75	125.00	200.00	312.50
Ratio Q_3/Q_1	315 , 250, 200, 160, 125 or 100			
Meter length (meter only) mm	122	122 or 142	142 or 162	162 or 182
Meter length (including flange adaptor) mm	200	200	200 or 225	250
Verification scale interval (m ³)	0.001			

(*) Accuracy class 2 only

Table 3 – Meter sizes, flowrates and related information

Meter size	DN125	DN150	DN200
Minimum flowrate Q_1 (m ³ /h)	1.27	2.00	3.17
Transitional flowrate Q_2 (m ³ /h) (*)	2.03	3.20	5.08
Maximum continuous flowrate Q_3 (m ³ /h)	400.00	630.00	1000.00
Overload flowrate Q_4 (m ³ /h)	500.00	787.50	1250.00
Ratio Q_3/Q_1	315, 250, 200, 160, 125 or 100		
Meter length (meter only) mm	182 or 202	202 or 231	231 or 302
Meter length (including flange adaptor) mm	250	300	350
Verification scale interval (m ³)	0.01		

(*) Accuracy class 2 only

5. Description of Variant 4

approved on 01/08/25

The Pattern and Variants are approved with an alternative marking arrangement as shown in Figure 7.

6. Description of Variant 5

approved on 01/08/25

The Pattern and Variants are approved with the software versions specified in Table 4. Software version information is marked on the meter.

Table 4 – Approved Software Versions

Version Number	Notes
P 236-1.00	Approved with pattern
A1.00	Provides support for the use of an alternative MCU.

TEST PROCEDURE No 14/3/52

This Approval and Certificate is issued only with respect to the design (the pattern and variants) of the water meter described herein. The calibration and measurement accuracy of individual water meters manufactured and marked in accordance with the approved pattern and variants should be verified in accordance with the test procedures specified below, or as required by relevant legislation.

Water meters tested for verification shall comply with the Certificate of Approval, Technical Schedule, and the maximum permissible errors for verification at the operating conditions in effect at the time of verification. Maximum permissible errors for the verification of water meters are given in the *National Trade Measurement Regulations 2009* (Cth).

Water meters shall be verified in accordance with the following national instrument test procedures:

- NITP 14.0 – Utility meters – general requirements
- NITP 14.3 – Utility meters – water meters

NOTE: NMI reserves the right to vary this procedure. Any such variation shall be notified in writing by NMI.

FIGURE 14/3/52 – 1




Elster Q4000 Electromagnetic model water meter – The Pattern

FIGURE 14/3/52 – 2



The flange adaptor

FIGURE 14/3/52 – 3



Display for: DN50 - DN100 Meters




Display for: DN125 – DN200 Meters



The indicating device

FIGURE 14/3/52 – 4



Sealing provisions

FIGURE 14/3/52 – 5







Required markings

FIGURE 14/3/52 – 6



Elster Q4000B Electromagnetic model water meter – Variant 2

FIGURE 14/3/52 – 7

	Existing Marking	New Marking
Dial Face (DN200LF Example)		
Label Marking (DN65LF Example)		

Alternative marking arrangement – Variant 4

~ End of Document ~