



CANCELLED

**NATIONAL STANDARDS COMMISSION**  
**WEIGHTS AND MEASURES (PATTERNS OF INSTRUMENTS) REGULATIONS**

**REGULATION 9**

**SUPPLEMENTARY CERTIFICATE OF APPROVAL No S167**

This is to certify that an approval has been granted by the Commission that the pattern and variant of the

Teraoka Seiko Model RW-300 Load Cell

submitted by J W Wedderburn & Sons Pty Ltd  
90 Parramatta Road  
Summer Hill NSW 2130

are suitable for use for trade.

This approval is subject to review on or after 1/7/89.

Instruments incorporating a load cell purporting to comply with this approval shall be marked NSC No S167 in addition to the approval number of the instrument.

This approval may be withdrawn if load cells are constructed and used other than as described in the drawings and specifications lodged with the Commission.

**Conditions of Approval**

1. The number of scale intervals applicable to the whole instrument shall be no greater than the number of verification scale intervals approved for the basework, or the load cell(s) or the headwork, whichever is the smallest.
2. The load cells to be used shall be subject to regular certification by the Commission.

Signed

Executive Director

**Descriptive Advice**

**Pattern:** approved 9/7/84

- . Teraoka Seiko model RW-300 load cell of 300 kg capacity.

**Variant:** approved 9/7/84

1. The RW series load cells in various capacities as listed in Table 1.

Technical Schedule No S167 describes the pattern and variant.

**Filing Advice**

The documentation for this approval comprises:

Supplementary Certificate of Approval No S167 dated 18/9/84  
Technical Schedule No S167 dated 18/9/84  
Table 1 dated 18/9/84  
Figure 1 dated 18/9/84



# NATIONAL STANDARDS COMMISSION

## TECHNICAL SCHEDULE No S167

Pattern: Teraoka Seiko Model RW-300 Load Cell

Submitter: J W Wedderburn & Sons Pty Ltd  
90 Parramatta Road  
Summer Hill NSW 2130

### 1. Description of Pattern

The pattern is a Teraoka Seiko model RW-300 load cell of 300 kg capacity (Figure 1 and Table 1) and is assembled in a Commission-approved basework.

#### 1.1 Method of Mounting

This beam load cell has one end, which may have a level indicator, attached to the main frame. The other end is bolted directly to the weighing platform frame without any intermediate levers or flexible joints.

#### 1.2 Marking

The following is the minimum data required to be marked on the load cell:

Manufacturer's name or mark  
Model number  
Serial number  
Maximum rated capacity  
Approval number

NSC No S167

### 2. Description of Variant 1

The RW series load cells in various capacities as listed in Table 1.

TABLE 1

| Type: Teraoka Seiko                            | RW-30                       | RW-60               | RW-150             | RW-300            |
|--|-----------------------------|---------------------|--------------------|-------------------|
| Maximum Capacity                               | 30 kg                       | 60 kg               | 150 kg             | 300 kg            |
| Maximum number of verification scale intervals | (a)*3000<br>(b)*2500        | 6000<br>5000        | 6000<br>2500       | 4500<br>2500      |
| Minimum dead load                              | 1.5 kg                      | 3 kg                | 7.5 kg             | 15 kg             |
| Minimum value of verification scale interval   | (a)*0.005 kg<br>(b)*0.01 kg | 0.005 kg<br>0.01 kg | 0.01 kg<br>0.05 kg | 0.02 kg<br>0.1 kg |
| Input impedance (nominal)                      | 350 $\Omega$                | 350 $\Omega$        | 350 $\Omega$       | 350 $\Omega$      |
| Output rating (nominal)                        | 1 mV/V                      | 1 mV/V              | 1 mV/V             | 1 mV/V            |
| Supply voltage (AC or DC)                      | 10 or 15 V                  | 10 or 15 V          | 10 or 15 V         | 10 or 15 V        |
| Cable length ( $\pm 0.1$ m)                    | 3 m                         | 3 m                 | 3 m                | 3 m               |
| Number of leads                                | 4 ¶                         | 4 ¶                 | 4 ¶                | 4 ¶               |

#### Teraoka Seiko RW Series Load Cells - Approved Capacities

\*The values listed as (a) and (b) represent respectively the allowable values when used with digital indicators, with and without automatic zero tracking.

¶ Plus shield



S167  
1/7/85

# NATIONAL STANDARDS COMMISSION

## NOTIFICATION OF CHANGE

### SUPPLEMENTARY CERTIFICATE OF APPROVAL No S167

#### CHANGE No 1

The following changes are made to the approval documentation for the

Teraoka Seiko Model RW-300 Load Cell

submitted by J W Wedderburn & Sons Pty Ltd  
90 Parramatta Road  
Summer Hill NSW 2130.

- 1) In Technical Schedule No S167 dated 18/9/84, Table 1 is replaced by the attached Table 1 (which now includes the RW-600 load cell of 600 kg capacity).
- 2) In Supplementary Certificate No S167 dated 18/9/84, the Filing Advice should be amended to read (in part):

Table 1 dated 1/7/85

Signed

Executive Director



# NATIONAL STANDARDS COMMISSION

S167  
7/11/86

## NOTIFICATION OF CHANGE

### SUPPLEMENTARY CERTIFICATE OF APPROVAL No S167

#### CHANGE No 2

The following changes are made to the approval documentation for the

Terodaka Seiko Model RW-300 Load Cell

submitted by J W Wedderburn & Sons Pty Ltd  
90 Parramatta Road  
Summer Hill NSW 2130.

- 1) In Technical Schedule No S167 dated 18/9/84, amend clause 1.1 Method of Mounting to read:

"Mounting is to be in accordance with one of the methods shown in Figure 2."

- 2) In Supplementary Certificate No S167 dated 18/9/84, the Filing Advice should be amended to read (in part):

"Figure 2 dated 7/11/86"

(Note: Figure 2 is attached herein.)

- 3) In Table 1 dated 1/7/85, amend the entry for the model RW-30 by adding a footnote, viz:

"\*\* Also known as a model RN-31."

Signed

Executive Director

TABLE 1


| Type: Teraoka Seiko                            | RW-30                       | RW-60               | RW-150             | RW-300            | RW-600           |
|--|-----------------------------|---------------------|--------------------|-------------------|------------------|
| Maximum Capacity                               | 30 kg                       | 60 kg               | 150 kg             | 300 kg            | 600 kg           |
| Maximum number of verification scale intervals | (a)*3000<br>(b)*2500        | 6000<br>5000        | 6000<br>2500       | 4500<br>2500      | 3000<br>3000     |
| Minimum dead load                              | 1.5 kg                      | 3 kg                | 7.5 kg             | 15 kg             | 30 kg            |
| Minimum value of verification scale interval   | (a)*0.005 kg<br>(b)*0.01 kg | 0.005 kg<br>0.01 kg | 0.01 kg<br>0.05 kg | 0.02 kg<br>0.1 kg | 0.1 kg<br>0.1 kg |
| Input impedance (nominal)                      | 350 $\Omega$                | 350 $\Omega$        | 350 $\Omega$       | 350 $\Omega$      | 350 $\Omega$     |
| Output rating (nominal)                        | 1 mV/V                      | 1 mV/V              | 1 mV/V             | 1 mV/V            | 1 mV/V           |
| Supply voltage (AC or DC)                      | 10 or 15 V                  | 10 or 15 V          | 10 or 15 V         | 10 or 15 V        | 10 or 15 V       |
| Cable length ( $\pm$ 0.1 m)                    | 3 m                         | 3 m                 | 3 m                | 3 m               | 3 m              |
| Number of leads                                | 4 ¶                         | 4 ¶                 | 4 ¶                | 4 ¶               | 4 ¶              |

## Teraoka Seiko RW Series Load Cells - Approved Capacities

\* The values listed as (a) and (b) represent respectively the allowable values when used with digital indicators, with and without automatic zero tracking.


¶ Plus shield

FIGURE S167 - 1



Terooka Seiko RW Series Load Cell

FIGURE S167 - 2



Mounting Methods